


Well W#37630 Information



Date Received		State	Iowa
Owner Name	Cedar Rapids, City Of	County	Linn
Alt Name	WEST 1	Quadrangle	Cedar Rapids North, Iowa
WNumber	37630	Township	T83N
PWTS ID	0	Range	R7W
PWS ID	5715093	Section	17
Storet ID	0	Quarter	NW SE NW
SDWIS ID	2409847	Latitude	42.0034770000
USGS ID	0	Longitude	-91.6912540000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	608382
		UTM Y	4650991
<hr/>			
Site Type	Drilled hole	Drilling Company	Layne Western - Ia.
Well Status	Plugged	Drilling Date	02/01/1964
Field Located	No	Drilling Method	Unknown
Elevation	709 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	66 ft
Landscape Position	Valley	Total Depth	66 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	02/01/1964		
Diameter	30.00 in	Depth	66.00 ft
Comments			

Casing Construction Information

Date	02/01/1964	Casing Type	Unknown
Start Depth	0.00 ft	End Depth	0.00 ft
Diameter	30.00 in	Amount	70.00 ft
Comments			

Screen Construction Information

Date	02/01/1964		
Screen Type	Unknown	Slot Size	0.00
Start Depth	0.00 ft	End Depth	0.00 ft
Diameter	0.00 in	Amount	10 ft
Comments			

Pump Construction Information

Date	02/01/1964	Pump Type	Turbine
Diameter	0.00 in	Rating	1000
Depth Intake	56.00 ft		
Comments			

Water Production Information

Date	01/01/1996	Start Time	
Aquifer	Unknown		
Static Water Level	24.00 ft	Yield	500 gallons per minute
Pumping Water Level	53 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	08/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	21.00 ft	Yield	750 gallons per minute
Pumping Water Level	46 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	04/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	21.00 ft	Yield	750 gallons per minute
Pumping Water Level	52 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	03/01/1994	Start Time	
Aquifer	Unknown		
Static Water Level	8.00 ft	Yield	793 gallons per minute
Pumping Water Level	49 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/37630/general-information>