


Well W#37635 Information



Date Received		State	Iowa
Owner Name	Cedar Rapids, City Of	County	Linn
Alt Name	WEST 6	Quadrangle	Cedar Rapids North, Iowa
WNumber	37635	Township	T83N
PWTS ID	0	Range	R7W
PWS ID	5715093	Section	7
Storet ID	0	Quarter	SE SW NE
SDWIS ID	2410876	Latitude	42.0103320000
USGS ID	0	Longitude	-91.7036250000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	607346
		UTM Y	4651736
<hr/>			
Site Type	Drilled hole	Drilling Company	Layne Western - Ia.
Well Status	Active	Drilling Date	01/01/1964
Field Located	No	Drilling Method	Unknown
Elevation	719 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	65 ft
Landscape Position	Valley	Total Depth	65 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	01/01/1964		
Diameter	30.00 in	Depth	65.00 ft
Comments			

Casing Construction Information

Date	01/01/1964	Casing Type	Unknown
Start Depth	0.00 ft	End Depth	0.00 ft
Diameter	30.00 in	Amount	0.00 ft
Comments			

Pump Construction Information

Date	01/01/1964	Pump Type	Turbine
Diameter	0.00 in	Rating	1200
Depth Intake	0.00 ft		
Comments			

Water Production Information

Date	01/01/1996	Start Time	
Aquifer	Unknown		
Static Water Level	14.00 ft	Yield	500 gallons per minute
Pumping Water Level	48 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	08/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	9.00 ft	Yield	700 gallons per minute
Pumping Water Level	39 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	04/05/1995	Start Time	
Aquifer	Unknown		
Static Water Level	20.00 ft	Yield	1000 gallons per minute
Pumping Water Level	55 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	09/01/1994	Start Time	
Aquifer	Unknown		
Static Water Level	9.00 ft	Yield	950 gallons per minute
Pumping Water Level	46 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	03/01/1994	Start Time	
Aquifer	Unknown		
Static Water Level	11.00 ft	Yield	1004 gallons per minute
Pumping Water Level	47 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/37635/general-information>