


Well W#38025 Information



| | | | |
|----------------------|---------------------------------|-------------------|-----------------------|
| Date Received | | State | Iowa |
| Owner Name | Green Acres Mobile Home Park | County | Des Moines |
| Alt Name | SMITH, JAMES L. | Quadrangle | Burlington, Iowa-III. |
| WNumber | 38025 | Township | T70N |
| PWTS ID | 0 | Range | R2W |
| PWS ID | 2900603 | Section | 20 |
| Storet ID | 0 | Quarter | NE NW SE |
| SDWIS ID | 2408731 | Latitude | 40.8530500000 |
| USGS ID | 0 | Longitude | -91.1088600000 |
| Project | Source Water Protection | Accuracy | |
| Operator | Unknown | UTM X | 659405 |
| | | UTM Y | 4524166 |

| | | | |
|---------------------------|---|-------------------------|-------------------------------|
| Site Type | Drilled hole | Drilling Company | Bailey Well Co. |
| Well Status | Active | Drilling Date | 09/22/1979 |
| Field Located | No | Drilling Method | Unknown |
| Elevation | 551 ft | Bedrock Depth | 0 ft |
| Elevation Accuracy | Digital Elevation Model Accurate to 5 ft | Well Depth | 71 ft |
| Landscape Position | Valley | Total Depth | 71 ft |
| | | Well Types | Public Supply, Subdivision |
| | | Aquifers | Alluvium |

Casing Construction Information

| | | | |
|--------------------|------------|--------------------|----------|
| Date | 09/22/1979 | Casing Type | Steel |
| Start Depth | 0.00 ft | End Depth | 25.00 ft |
| Diameter | 12.00 in | Amount | 0.00 ft |
| Comments | | | |

Screen Construction Information

| | | | |
|--------------------|------------|------------------|----------|
| Date | 09/22/1979 | Slot Size | 0.10 |
| Screen Type | Steel | End Depth | 30.00 ft |
| Start Depth | 4.50 ft | Amount | 5 ft |
| Diameter | 5.25 in | | |
| Comments | | | |

Water Production Information

| | | | |
|----------------------------|----------|---------------------|----------------------|
| Date | | Start Time | |
| Aquifer | Unknown | Yield | 0 gallons per minute |
| Static Water Level | 28.00 ft | Yield Method | Unknown |
| Pumping Water Level | 30 ft | Pump Test | Yes |
| Measurement | Unknown | Duration | 0 mins |
| Pump Method | Unknown | | |
| Comments | | | |

<https://www.iihr.uiowa.edu/igs/geosam/well/38025/general-information>