


Well W#39056 Information



Date Received		State	Iowa
Owner Name	Decorah, City Of	County	Winneshiek
Alt Name	#6	Quadrangle	Decorah, Iowa
WNumber	39056	Township	T98N
PWTS ID	0	Range	R8W
PWS ID	9630012	Section	16
Storet ID	31960001	Quarter	NE SW SW
SDWIS ID	2412963	Latitude	43.3077940000
USGS ID	431828091473201	Longitude	-91.7924680000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	597932
		UTM Y	4795704

Site Type	Drilled hole	Drilling Company	Nelson Bros.
Well Status	Active	Drilling Date	01/01/1972
Field Located	No	Drilling Method	Rotary
Elevation	859 ft	Bedrock Depth	62 ft
Elevation Accuracy	Digital Elevation Model	Well Depth	82 ft
	Accurate to 5 ft	Total Depth	82 ft
Landscape Position	Valley	Well Types	Municipal, Public Supply
		Aquifers	Alluvium, Cambrian-Ordovician

Casing Construction Information

Date	01/01/1972	Casing Type	Unknown
Start Depth	0.00 ft	End Depth	46.70 ft
Diameter	16.00 in	Amount	0.00 ft
Comments			

Date	01/01/1972	Casing Type	Unknown
Start Depth	61.70 ft	End Depth	81.70 ft
Diameter	14.00 in	Amount	0.00 ft
Comments			

Screen Construction Information

Date	01/01/1972	Slot Size	0.00
Screen Type	Unknown	End Depth	61.70 ft
Start Depth	44.70 ft	Amount	0 ft
Diameter	16.00 in		
Comments			

Pump Construction Information

Date	01/01/1972	Pump Type	Turbine
Diameter	0.00 in	Rating	435
Depth Intake	0.00 ft		
Comments			

Log Information

Date	
Log Types	Drillers log
Prepared By	Unknown
Comments	

Water Production Information

Date	01/24/2001	Start Time	
Aquifer	Unknown	Yield	0 gallons per minute
Static Water Level	16.00 ft	Yield Method	Unknown
Pumping Water Level	43 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

Date	12/13/2000	Start Time	
Aquifer	Unknown		
Static Water Level	15.00 ft	Yield	0 gallons per minute
Pumping Water Level	42 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	08/09/2000	Start Time	
Aquifer	Unknown		
Static Water Level	15.00 ft	Yield	0 gallons per minute
Pumping Water Level	43 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	05/17/2000	Start Time	
Aquifer	Unknown		
Static Water Level	17.00 ft	Yield	0 gallons per minute
Pumping Water Level	45 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	05/05/2000	Start Time	08:45
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	45 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	20 mins
Comments			

Date	11/23/1999	Start Time	02:20
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	43 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	10/13/1999	Start Time	
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	42 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	09/01/1999	Start Time	01:20
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	42 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			
Date	02/01/1999	Start Time	
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	43 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			
Date	09/23/1998	Start Time	
Aquifer	Unknown		
Static Water Level	16.00 ft	Yield	0 gallons per minute
Pumping Water Level	42 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			
Date	08/19/1998	Start Time	01:35
Aquifer	Unknown		
Static Water Level	15.00 ft	Yield	0 gallons per minute
Pumping Water Level	42 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			
Date	10/28/1997	Start Time	01:00
Aquifer	Unknown		
Static Water Level	19.00 ft	Yield	0 gallons per minute
Pumping Water Level	44 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			
Date	01/01/1983	Start Time	
Aquifer	Unknown		
Static Water Level	13.00 ft	Yield	555 gallons per minute
Pumping Water Level	39 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	01/01/1979	Start Time	
Aquifer	Unknown		
Static Water Level	7.00 ft	Yield	500 gallons per minute
Pumping Water Level	26 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	2400 mins
Comments			

Date		Start Time	
Aquifer	Unknown		
Static Water Level	10.00 ft	Yield	500 gallons per minute
Pumping Water Level	30 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/39056/general-information>