


Well W#39099 Information



Date Received		State	Iowa
Owner Name	Denison, City Of	County	Crawford
Alt Name		Quadrangle	Denison, Iowa
WNumber	39099	Township	T83N
PWTS ID	0	Range	R39W
PWS ID	2424027	Section	10
Storet ID	0	Quarter	NE SE NW
SDWIS ID	2413578	Latitude	42.0185990000
USGS ID	0	Longitude	-95.3672600000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	304000
		UTM Y	4654552

Site Type	Drilled hole	Drilling Company	Layne Western - Ia.
Well Status	Not Used	Drilling Date	10/11/1972
Field Located	No	Drilling Method	Unknown
Elevation	1159 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	61 ft
Landscape Position	Valley	Total Depth	61 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	10/11/1972	Depth	61.00 ft
Diameter	42.00 in		

Comments

Casing Construction Information

Date	10/11/1972	Casing Type	Unknown
Start Depth	-9.00 ft	End Depth	41.00 ft
Diameter	18.00 in	Amount	50.00 ft
Comments			

Screen Construction Information

Date	10/11/1972	Slot Size	0.00
Screen Type	Unknown	End Depth	61.00 ft
Start Depth	41.00 ft	Amount	0 ft
Diameter	18.00 in		
Comments			

Grout Construction Information

Date	10/11/1972	Grout Placement	Unknown
Grout Type	Unknown	End Depth	20.00 ft
Start Depth	0.00 ft		
Comments			

Gravel Pack Construction Information

Date	10/11/1972	Slot Size	
Gravel Pack Type	Unknown	End Depth	61.00 ft
Start Depth	20.00 ft		
Comments			

Pump Construction Information

Date	10/11/1972	Pump Type	Turbine
Diameter	0.00 in	Rating	500
Depth Intake	0.00 ft		
Comments			

Log Information

Date	
Log Types	Drillers log
Prepared By	Unknown
Comments	

Water Production Information

Date	10/11/1972	Start Time	01:00
Aquifer	Unknown		
Static Water Level	22.00 ft	Yield	800 gallons per minute
Pumping Water Level	35 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	400 mins
Comments			

Date	10/11/1972	Start Time	02:00
Aquifer	Unknown		
Static Water Level	22.00 ft	Yield	781 gallons per minute
Pumping Water Level	32 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	100 mins
Comments			

Date	01/01/1972	Start Time	
Aquifer	Unknown		
Static Water Level	22.00 ft	Yield	781 gallons per minute
Pumping Water Level	32 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	100 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/39099/general-information>