


Well W#39563 Information



Date Received		State	Iowa
Owner Name	Earling, City Of	County	Shelby
Alt Name	68-1	Quadrangle	Earling, Iowa
WNumber	39563	Township	T80N
PWTS ID	0	Range	R39W
PWS ID	8320098	Section	5
Storet ID	0	Quarter	NW NE SW
SDWIS ID	2412980	Latitude	41.7733300000
USGS ID	0	Longitude	-95.4164600000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	299159
		UTM Y	4627432

Site Type	Drilled hole	Drilling Company	Layne Western - Ia.
Well Status	Active	Drilling Date	11/21/1968
Field Located	No	Drilling Method	Rotary
Elevation	1297 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	40 ft
Landscape Position	Valley	Total Depth	40 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	11/21/1968	Depth	40.00 ft
Diameter	30.00 in		

Comments

Casing Construction Information

Date	11/21/1968	Casing Type	Steel
Start Depth	-0.50 ft	End Depth	30.00 ft
Diameter	6.00 in	Amount	30.50 ft
Comments			

Screen Construction Information

Date	11/21/1968	Slot Size	0.08
Screen Type	Steel	End Depth	40.00 ft
Start Depth	30.00 ft	Amount	10 ft
Diameter	6.00 in		
Comments			

Grout Construction Information

Date	11/21/1968	Grout Placement	Unknown
Grout Type	Unknown	End Depth	10.00 ft
Start Depth	0.00 ft		
Comments			

Gravel Pack Construction Information

Date	11/21/1968	Slot Size	
Gravel Pack Type	Unknown	End Depth	40.00 ft
Start Depth	10.00 ft		
Comments			

Pump Construction Information

Date	11/21/1968	Pump Type	Submersible
Diameter	0.00 in	Rating	25
Depth Intake	30.00 ft		
Comments			

Log Information

Date	
Log Types	Drillers log
Prepared By	Unknown
Comments	

Water Production Information

Date	10/01/2000	Start Time	
Aquifer	Unknown		
Static Water Level	7.00 ft	Yield	0 gallons per minute
Pumping Water Level	24 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	11/21/1968	Start Time	09:00
Aquifer	Unknown		
Static Water Level	7.00 ft	Yield	35 gallons per minute
Pumping Water Level	24 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Pumped	Duration	800 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/39563/general-information>