


Well W#39761 Information



Date Received		State	Iowa
Owner Name	Farley, City Of	County	Dubuque
Alt Name	#1	Quadrangle	Dyersville East, Iowa
WNumber	39761	Township	T88N
PWTS ID	0	Range	R1W
PWS ID	3135018	Section	7
Storet ID	0	Quarter	SW SE NE
SDWIS ID	2411609	Latitude	42.4434890000
USGS ID	0	Longitude	-91.0054800000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	664032
		UTM Y	4700945

Site Type	Drilled hole	Drilling Company	Not Listed
Well Status	Standby	Drilling Date	01/01/1894
Field Located	No	Drilling Method	Unknown
Elevation	1116 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	208 ft
Landscape Position	Unknown	Total Depth	208 ft
		Well Types	Municipal, Public Supply
		Aquifers	Silurian

Hole Construction Information

Date	01/01/1894	Depth	208.00 ft
Diameter	6.00 in		

Comments

Casing Construction Information

Date	01/01/1894	Casing Type	Steel
Start Depth	0.00 ft	End Depth	0.00 ft
Diameter	0.00 in	Amount	0.00 ft
Comments			

Screen Construction Information

Date	01/01/1894	Slot Size	0.00
Screen Type	Steel	End Depth	0.00 ft
Start Depth	0.00 ft	Amount	0 ft
Diameter	0.00 in		
Comments			

Pump Construction Information

Date	01/01/1894	Pump Type	Submersible
Diameter	0.00 in	Rating	45
Depth Intake	0.00 ft		
Comments			

Water Production Information

Date	01/26/2000	Start Time	
Aquifer	Unknown	Yield	40 gallons per minute
Static Water Level	86.00 ft	Yield Method	Unknown
Pumping Water Level	104 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

Date	01/01/1975	Start Time	
Aquifer	Unknown	Yield	45 gallons per minute
Static Water Level	80.00 ft	Yield Method	Unknown
Pumping Water Level	100 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

Date	01/01/1944	Start Time	
Aquifer	Unknown	Yield	65 gallons per minute
Static Water Level	40.00 ft		

Pumping Water Level	110 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	01/01/1944	Start Time	
Aquifer	Unknown	Yield	65 gallons per minute
Static Water Level	40.00 ft	Yield Method	Unknown
Pumping Water Level	110 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

<https://www.ihr.uiowa.edu/igs/geosam/well/39761/general-information>