


# Well W#41436 Information



<b>Date Received</b>		<b>State</b>	Iowa
<b>Owner Name</b>	Perry, City Of	<b>County</b>	Dallas
<b>Alt Name</b>	#8	<b>Quadrangle</b>	Perry, Iowa
<b>WNumber</b>	41436	<b>Township</b>	T81N
<b>PWTS ID</b>	0	<b>Range</b>	R28W
<b>PWS ID</b>	2561036	<b>Section</b>	9
<b>Storet ID</b>	0	<b>Quarter</b>	NE NW SW
<b>SDWIS ID</b>	2409561	<b>Latitude</b>	41.8468400000
<b>USGS ID</b>	0	<b>Longitude</b>	-94.1142990000
<b>Project</b>	Source Water Protection	<b>Accuracy</b>	
<b>Operator</b>	Unknown	<b>UTM X</b>	407495
		<b>UTM Y</b>	4633371

<b>Site Type</b>	Drilled hole	<b>Drilling Company</b>	Thorpe Well Co.
<b>Well Status</b>	Not Used	<b>Drilling Date</b>	01/01/1954
<b>Field Located</b>	No	<b>Drilling Method</b>	Rotary
<b>Elevation</b>	950 ft	<b>Bedrock Depth</b>	0 ft
<b>Elevation Accuracy</b>	Digital Elevation Model Accurate to 5 ft	<b>Well Depth</b>	40 ft
<b>Landscape Position</b>	Unknown	<b>Total Depth</b>	0 ft
		<b>Well Types</b>	Municipal, Public Supply
		<b>Aquifers</b>	Alluvium

## Casing Construction Information

<b>Date</b>	01/01/1954	<b>Casing Type</b>	Unknown
<b>Start Depth</b>	0.00 ft	<b>End Depth</b>	0.00 ft

<b>Diameter</b>	16.00 in	<b>Amount</b>	0.00 ft
<b>Comments</b>			

---

<b>Date</b>	01/01/1954	<b>Casing Type</b>	Unknown
<b>Start Depth</b>	0.00 ft	<b>End Depth</b>	0.00 ft
<b>Diameter</b>	10.00 in	<b>Amount</b>	0.00 ft
<b>Comments</b>			

## Water Production Information

<b>Date</b>	01/01/1988	<b>Start Time</b>	
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	8.00 ft	<b>Yield</b>	80 gallons per minute
<b>Pumping Water Level</b>	21 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			

---

<b>Date</b>	01/01/1983	<b>Start Time</b>	
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	20.00 ft	<b>Yield</b>	100 gallons per minute
<b>Pumping Water Level</b>	28 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			

---

<b>Date</b>	01/01/1954	<b>Start Time</b>	
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	8.00 ft	<b>Yield</b>	175 gallons per minute
<b>Pumping Water Level</b>	0 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			

---

<b>Date</b>	01/01/1954	<b>Start Time</b>	
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	8.00 ft	<b>Yield</b>	275 gallons per minute
<b>Pumping Water Level</b>	28 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			