

# Well W#41791 Information



<b>Date Received</b>		<b>State</b>	Iowa
<b>Owner Name</b>	Regional Water	<b>County</b>	Shelby
<b>Alt Name</b>	#3	<b>Quadrangle</b>	Corley, Iowa
<b>WNumber</b>	41791	<b>Township</b>	T78N
<b>PWTS ID</b>	0	<b>Range</b>	R39W
<b>PWS ID</b>	8300184	<b>Section</b>	33
<b>Storet ID</b>	0	<b>Quarter</b>	SW SW NE
<b>SDWIS ID</b>	2408439	<b>Latitude</b>	41.5093070000
<b>USGS ID</b>	0	<b>Longitude</b>	-95.3430720000
<b>Project</b>	Source Water Protection	<b>Accuracy</b>	
<b>Operator</b>	Unknown	<b>UTM X</b>	304462
		<b>UTM Y</b>	4597948

<b>Site Type</b>	Drilled hole	<b>Drilling Company</b>	Thorpe Well Co.
<b>Well Status</b>	Active	<b>Drilling Date</b>	01/01/1977
<b>Field Located</b>	No	<b>Drilling Method</b>	Rotary
<b>Elevation</b>	1150 ft	<b>Bedrock Depth</b>	0 ft
<b>Elevation Accuracy</b>	Digital Elevation Model Accurate to 5 ft	<b>Well Depth</b>	27 ft
<b>Landscape Position</b>	Unknown	<b>Total Depth</b>	27 ft
		<b>Well Types</b>	Municipal, Public Supply
		<b>Aquifers</b>	Alluvium

## Casing Construction Information

<b>Date</b>	01/01/1977	<b>Casing Type</b>	Steel
<b>Start Depth</b>	0.00 ft	<b>End Depth</b>	22.00 ft

<b>Diameter</b>	8.00 in	<b>Amount</b>	0.00 ft
<b>Comments</b>			

## Screen Construction Information

<b>Date</b>	01/01/1977		
<b>Screen Type</b>	Steel	<b>Slot Size</b>	0.00
<b>Start Depth</b>	0.00 ft	<b>End Depth</b>	0.00 ft
<b>Diameter</b>	0.00 in	<b>Amount</b>	5 ft
<b>Comments</b>			

## Grout Construction Information

<b>Date</b>	01/01/1977		
<b>Grout Type</b>	Cement	<b>Grout Placement</b>	Unknown
<b>Start Depth</b>	0.00 ft	<b>End Depth</b>	10.00 ft
<b>Comments</b>			

## Pump Construction Information

<b>Date</b>	01/01/1977	<b>Pump Type</b>	Submersible
<b>Diameter</b>	0.00 in	<b>Rating</b>	75
<b>Depth Intake</b>	0.00 ft		
<b>Comments</b>			

## Water Production Information

<b>Date</b>	01/01/1977	<b>Start Time</b>	01:00
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	14.00 ft	<b>Yield</b>	0 gallons per minute
<b>Pumping Water Level</b>	0 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			

---

<b>Date</b>	01/01/1977	<b>Start Time</b>	02:00
<b>Aquifer</b>	Unknown		
<b>Static Water Level</b>	21.00 ft	<b>Yield</b>	34 gallons per minute
<b>Pumping Water Level</b>	23 ft	<b>Yield Method</b>	Unknown
<b>Measurement</b>	Unknown	<b>Pump Test</b>	Yes
<b>Pump Method</b>	Unknown	<b>Duration</b>	0 mins
<b>Comments</b>			