


Well W#43042 Information



Date Received		State	Iowa
Owner Name	Waterloo, City Of	County	Black Hawk
Alt Name	Well #11	Quadrangle	Waterloo North, Iowa
WNumber	43042	Township	T89N
PWTS ID	0	Range	R13W
PWS ID	790074	Section	15
Storet ID	0	Quarter	SE NE NW
SDWIS ID	2411865	Latitude	42.5189710000
USGS ID	0	Longitude	-92.3606980000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	552513
		UTM Y	4707598

Site Type	Drilled hole	Drilling Company	Thorpe Well Co.
Well Status	Active	Drilling Date	07/03/1939
Field Located	No	Drilling Method	Unknown
Elevation	851 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	82 ft
Landscape Position	Unknown	Total Depth	82 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	07/03/1939	Depth	0.00 ft
Diameter	78.00 in		

Comments

Date	07/03/1939	Depth	82.00 ft
Diameter	42.00 in		
Comments			

Casing Construction Information

Date	07/03/1939	Casing Type	Unknown
Start Depth	6.00 ft	End Depth	32.00 ft
Diameter	40.00 in	Amount	0.00 ft
Comments			

Date	07/03/1939	Casing Type	Unknown
Start Depth	0.00 ft	End Depth	30.80 ft
Diameter	24.00 in	Amount	30.80 ft
Comments			

Screen Construction Information

Date	07/03/1939	Slot Size	0.00
Screen Type	Unknown	End Depth	80.80 ft
Start Depth	30.80 ft	Amount	50 ft
Diameter	24.00 in		
Comments			

Pump Construction Information

Date	07/03/1939	Pump Type	Turbine
Diameter	0.00 in	Rating	1875
Depth Intake	0.00 ft		
Comments			

Log Information

Date	
Log Types	Drillers log
Prepared By	Waterloo, City Of
Comments	

Water Production Information

Date	03/15/2001	Start Time	
Aquifer	Unknown		

Static Water Level	24.00 ft	Yield	1933 gallons per minute
Pumping Water Level	36 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	01/01/1939	Start Time	
Aquifer	Unknown		
Static Water Level	17.00 ft	Yield	2340 gallons per minute
Pumping Water Level	38 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/43042/general-information>