


# Well W#43043 Information



<b>Date Received</b>		<b>State</b>	Iowa
<b>Owner Name</b>	Waterloo, City Of	<b>County</b>	Black Hawk
<b>Alt Name</b>	Well #12	<b>Quadrangle</b>	Waterloo North, Iowa
<b>WNumber</b>	43043	<b>Township</b>	T89N
<b>PWTS ID</b>	0	<b>Range</b>	R13W
<b>PWS ID</b>	790074	<b>Section</b>	15
<b>Storet ID</b>	0	<b>Quarter</b>	SE NE SE
<b>SDWIS ID</b>	2407195	<b>Latitude</b>	42.5183430000
<b>USGS ID</b>	0	<b>Longitude</b>	-92.3586840000
<b>Project</b>	Source Water Protection	<b>Accuracy</b>	
<b>Operator</b>	Unknown	<b>UTM X</b>	552679
		<b>UTM Y</b>	4707529

---

<b>Site Type</b>	Drilled hole	<b>Drilling Company</b>	Thorpe Well Co.
<b>Well Status</b>	Active	<b>Drilling Date</b>	07/17/1941
<b>Field Located</b>	No	<b>Drilling Method</b>	Unknown
<b>Elevation</b>	854 ft	<b>Bedrock Depth</b>	0 ft
<b>Elevation Accuracy</b>	Digital Elevation Model Accurate to 5 ft	<b>Well Depth</b>	89 ft
<b>Landscape Position</b>	Unknown	<b>Total Depth</b>	89 ft
		<b>Well Types</b>	Municipal, Public Supply
		<b>Aquifers</b>	Alluvium

## Hole Construction Information

<b>Date</b>	07/17/1941	<b>Depth</b>	0.00 ft
<b>Diameter</b>	96.00 in		

## Comments

---

Date	07/17/1941	Depth	89.00 ft
Diameter	46.00 in		
Comments			

## Casing Construction Information

Date	07/17/1941	Casing Type	Unknown
Start Depth	2.50 ft	End Depth	39.00 ft
Diameter	24.00 in	Amount	36.50 ft
Comments			

## Screen Construction Information

Date	07/17/1941	Slot Size	0.00
Screen Type	Unknown	End Depth	89.00 ft
Start Depth	39.00 ft	Amount	50 ft
Diameter	24.00 in		
Comments			

## Pump Construction Information

Date	07/17/1941	Pump Type	Turbine
Diameter	0.00 in	Rating	3333
Depth Intake	0.00 ft		
Comments			

## Water Production Information

Date	03/15/2001	Start Time	
Aquifer	Unknown	Yield	1850 gallons per minute
Static Water Level	26.00 ft	Yield Method	Unknown
Pumping Water Level	36 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

---

Date	07/17/1941	Start Time	
Aquifer	Unknown	Yield	4166 gallons per minute
Static Water Level	16.00 ft	Yield Method	Unknown
Pumping Water Level	28 ft	Pump Test	Yes
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

<https://www.ihr.uiowa.edu/igs/geosam/well/43043/general-information>