


Well W#43044 Information



Date Received		State	Iowa
Owner Name	Waterloo, City Of	County	Black Hawk
Alt Name	Well #13	Quadrangle	Waterloo North, Iowa
WNumber	43044	Township	T89N
PWTS ID	0	Range	R13W
PWS ID	790074	Section	15
Storet ID	0	Quarter	SE NE SE
SDWIS ID	2407519	Latitude	42.5175820000
USGS ID	0	Longitude	-92.3586590000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	552682
		UTM Y	4707445

Site Type	Drilled hole	Drilling Company	Thorpe Well Co.
Well Status	Active	Drilling Date	06/30/1948
Field Located	No	Drilling Method	Unknown
Elevation	852 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	82 ft
Landscape Position	Unknown	Total Depth	82 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	06/30/1948	Depth	0.00 ft
Diameter	94.00 in		

Comments

Date	06/30/1948	Depth	82.00 ft
Diameter	54.00 in		
Comments			

Casing Construction Information

Date	06/30/1948	Casing Type	Unknown
Start Depth	-8.30 ft	End Depth	31.50 ft
Diameter	26.00 in	Amount	39.80 ft
Comments			

Date	06/30/1948	Casing Type	Unknown
Start Depth	29.00 ft	End Depth	32.00 ft
Diameter	22.00 in	Amount	3.00 ft
Comments			

Screen Construction Information

Date	06/30/1948	Slot Size	0.00
Screen Type	Unknown	End Depth	82.00 ft
Start Depth	32.00 ft	Amount	50 ft
Diameter	24.00 in		
Comments			

Pump Construction Information

Date	06/30/1948	Pump Type	Turbine
Diameter	0.00 in	Rating	1944
Depth Intake	0.00 ft		
Comments			

Log Information

Date	
Log Types	Drillers log
Prepared By	Waterloo, City Of
Comments	

Water Production Information

Date	03/15/2001	Start Time	
Aquifer	Unknown		

Static Water Level	26.00 ft	Yield	1833 gallons per minute
Pumping Water Level	35 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	06/30/1978	Start Time	
Aquifer	Unknown		
Static Water Level	18.00 ft	Yield	2200 gallons per minute
Pumping Water Level	33 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/43044/general-information>