


Well W#43190 Information



Date Received		State	Iowa
Owner Name	Cedar Rapids, City Of	County	Linn
Alt Name	#52	Quadrangle	Cedar Rapids North, Iowa
WNumber	43190	Township	T83N
PWTS ID	0	Range	R8W
PWS ID	5715093	Section	14
Storet ID	0	Quarter	NE NW NW
SDWIS ID	2408919	Latitude	42.0062250000
USGS ID	0	Longitude	-91.7445540000
Project Operator	Source Water Protection Unknown	Accuracy	
		UTM X	603964
		UTM Y	4651230
<hr/>			
Site Type	Drilled hole	Drilling Company	Unknown
Well Status	Active	Drilling Date	01/01/1991
Field Located	No	Drilling Method	Unknown
Elevation	729 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	52 ft
Landscape Position	Valley	Total Depth	52 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Hole Construction Information

Date	02/01/1991		
Diameter	0.00 in	Depth	52.00 ft
Comments			

Screen Construction Information

Date	02/01/1991		
Screen Type	Unknown	Slot Size	0.90
Start Depth	0.00 ft	End Depth	0.00 ft
Diameter	30.00 in	Amount	15 ft
Comments			

Water Production Information

Date	10/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	13.00 ft	Yield	800 gallons per minute
Pumping Water Level	27 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	06/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	9.00 ft	Yield	1200 gallons per minute
Pumping Water Level	25 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	03/01/1995	Start Time	
Aquifer	Unknown		
Static Water Level	9.00 ft	Yield	1150 gallons per minute
Pumping Water Level	28 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	07/01/1994	Start Time	
Aquifer	Unknown		
Static Water Level	9.00 ft	Yield	1200 gallons per minute
Pumping Water Level	23 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins

Comments

Date	03/01/1994	Start Time	
Aquifer	Unknown		
Static Water Level	11.00 ft	Yield	1530 gallons per minute
Pumping Water Level	32 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

<https://www.ihr.uiowa.edu/igs/geosam/well/43190/general-information>