


Well W#47722 Information



Date Received		State	Iowa
Owner Name	Holstein, City Of	County	Ida
Alt Name	NORTH	Quadrangle	Ida Grove Nw, Iowa
WNumber	47722	Township	T88N
PWTS ID	0	Range	R40W
PWS ID	4721054	Section	1
Storet ID	0	Quarter	NE NE SW
SDWIS ID	2408812	Latitude	42.4719000000
USGS ID	0	Longitude	-95.4421700000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	299241
		UTM Y	4705063

Site Type	Drilled hole	Drilling Company	Unknown
Well Status	Active	Drilling Date	11/13/1995
Field Located	No	Drilling Method	Rotary
Elevation	1250 ft	Bedrock Depth	0 ft
Elevation Accuracy	Digital Elevation Model Accurate to 5 ft	Well Depth	40 ft
Landscape Position	Valley	Total Depth	40 ft
		Well Types	Municipal, Public Supply
		Aquifers	Alluvium

Casing Construction Information

Date	11/13/1995	Casing Type	PVC
Start Depth	-6.00 ft	End Depth	35.00 ft

Diameter	8.00 in	Amount	0.00 ft
Comments			

Screen Construction Information

Date	11/13/1995		
Screen Type	PVC	Slot Size	0.00
Start Depth	35.00 ft	End Depth	40.00 ft
Diameter	8.00 in	Amount	5 ft
Comments			

Pump Construction Information

Date	11/13/1995	Pump Type	Submersible
Diameter	4.00 in	Rating	93
Depth Intake	0.00 ft		
Comments			

Log Information

Date	
Log Types	Unknown
Prepared By	Unknown
Comments	

Water Production Information

Date	07/31/1998	Start Time	
Aquifer	Unknown		
Static Water Level	22.00 ft	Yield	0 gallons per minute
Pumping Water Level	28 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	08/04/1997	Start Time	
Aquifer	Unknown		
Static Water Level	22.00 ft	Yield	0 gallons per minute
Pumping Water Level	28 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	09/30/1996	Start Time	
Aquifer	Unknown		

Static Water Level	21.00 ft	Yield	0 gallons per minute
Pumping Water Level	28 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Unknown	Duration	0 mins
Comments			

Date	11/10/1995	Start Time	
Aquifer	Unknown		
Static Water Level	8.00 ft	Yield	70 gallons per minute
Pumping Water Level	13 ft	Yield Method	Unknown
Measurement	Unknown	Pump Test	Yes
Pump Method	Pumped	Duration	140 mins
Comments			

<https://www.iuhr.uiowa.edu/igs/geosam/well/47722/general-information>