


Well W#67463 Information



Date Received		State	Iowa
Owner Name	Cherokee Rwd Cherokee Subsystem	County	Cherokee
Alt Name	C-3	Quadrangle	Cherokee South, Iowa
WNumber	67463	Township	T91N
PWTS ID	0	Range	R40W
PWS ID	1811001	Section	28
Storet ID	0	Quarter	NE NE SW
SDWIS ID	2584837	Latitude	42.6750780000
USGS ID	0	Longitude	-95.5676990000
Project	Source Water Protection	Accuracy	
Operator	Unknown	UTM X	289606
		UTM Y	4727931

Site Type	Drilled hole	Drilling Company	Sargent Drilling
Well Status	Plugged	Drilling Date	12/03/2003
Field Located	No	Drilling Method	Unknown
Elevation	1198 ft	Bedrock Depth	0 ft
Elevation Accuracy	Topo Map Accurate to 2 ft	Well Depth	251 ft
Landscape Position	Valley	Total Depth	251 ft
		Well Types	Municipal, Public Supply
		Aquifers	Dakota/Cretaceous

Hole Construction Information

Date	12/03/2003	Depth	251.00 ft
Diameter	24.00 in		

Comments

Casing Construction Information

Date	12/03/2003	Casing Type	Steel
Start Depth	2.00 ft	End Depth	176.00 ft
Diameter	12.00 in	Amount	0.00 ft
Comments			

Screen Construction Information

Date	12/03/2003	Slot Size	0.03
Screen Type	Steel	End Depth	251.00 ft
Start Depth	176.00 ft	Amount	0 ft
Diameter	12.00 in		
Comments			

Grout Construction Information

Date	12/03/2003	Grout Placement	Unknown
Grout Type	Bentonite (Clay)	End Depth	125.00 ft
Start Depth	60.00 ft		
Comments			

Date	12/03/2003	Grout Placement	Unknown
Grout Type	Cement	End Depth	60.00 ft
Start Depth	2.00 ft		
Comments			

Gravel Pack Construction Information

Date	12/03/2003	Slot Size	
Gravel Pack Type	Gravel	End Depth	251.00 ft
Start Depth	125.00 ft		
Comments	chlorinated gravel		

Pump Construction Information

Date	12/03/2003	Pump Type	Unknown
Diameter	6.00 in	Rating	0
Depth Intake	120.00 ft		
Comments			

Log Information

Date	12/21/2021
Log Types	Unknown
Prepared By	Unknown
Comments	plugging record

Date	10/14/2003
Log Types	Drillers log
Prepared By	Sargent Drilling
Comments	

Water Production Information

Date	12/03/2003	Start Time	
Aquifer	Quaternary	Yield	0 gallons per minute
Static Water Level	17.00 ft	Yield Method	Unknown
Pumping Water Level	0 ft	Pump Test	No
Measurement	Unknown	Duration	0 mins
Pump Method	Unknown		
Comments			

<https://www.iihr.uiowa.edu/igs/geosam/well/67463/general-information>