

54624

NORTHWAY WELL AND PUMP COMPANY

4895 8th Avenue
Marion, Iowa 52302
319-377-6339

100 North 6th Street
Waukeg, Iowa 50263
515-987-4575

WELL TEST DATA REPORT

Customer City of Marion City Marion, Iowa
Location Hawthorne Street Well No. 6
Size Casing 22" & 18" Total Depth 1596' Construction Steel
Pump Make National Model No. M14XXHC No. of Stages 4
Diameter 14" Total Setting 455 Air Line Length 455
Meter Used 8" Static Level 330'

							TEMP. DISCHARGE
DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	DESCRIPTION
3-8-00	11:30	1450				10	
AM	11:45	1720	412'			0	
PM	12:00	1700	415'				
	12:15	1650	419'				
	12:30	1650	420'				
	12:45	1600	420'	90'	17.77		
	1:15	1600	421'				
	1:45	1600	423'		17.20		
	2:15	1600	424'				
	2:45	1600	425'	95'	16.84		
	3:15	1600	425'	95'			
	3:45	1600	429'	99'	16.32	16.16	Changed gauges, draw down
	4:15	1600	429'				
	4:45	1600	429'				
	5:15	1600	429'		16.16		
	5:45	1600	429½'				
	6:15	1580	429½'				
	6:45	1580	430'	100'	15.8		
	7:15	1580	430½'				
	7:45	1580	430½'				
	8:45	1580	431	101'	15.64		
	9:45	1580	431	101'	15.64		
	10:45	1580	431½'	101.5'	15.56		
	11:45	1580	431½'	101.5'	15.56		
AM	12:45	1580	432	102'	15.49		

This test was performed after acidizing with 9500 gallons of
muriatic acid.