

SHAWVER WELL COMPANY, INC.

TEST PUMPING REPORT

Project:	Nevel Properties - Agri-Processors	Well ID:	No. 3
Location:	Postville, IA	Date:	5/17/2006
Test Pump Crew:	Jim Sass/Peerless Service	Miscellaneous Info: Agri - Turkey well - observation well at 7:00 p.m. - 216'	
Depth of Well:	1,372'		
Size of Well:	14"		
SWL:	462'		
Pump Model:	4 - stage - 55 PGM		
Pump HP:	200 HP		
Orifice Size:	6" Meter		
Length of Airline:	642'		
Depth of Pump:	642'		

Time	GPM	PWL (air)	PWL (elec.)	Ph	Temp	Character of Water/Pumping Details
7:00 PM						
7:01 PM	700	540'				
7:02 PM	700	546'				
7:03 PM	700	547'				
7:04 PM	700	548'				
7:05 PM	700	550'				
7:06 PM		552'				
7:07 PM		553'				
7:08 PM		554'				
7:09 PM		554'				
7:10 PM	700	555'				210, 214, 222 AMPS
7:15 PM		558'				Water - Rusty Color (Red)
7:20 PM		559'				
7:25 PM		561'				Water - Clear
7:30 PM	700	562'				No Sand
7:45 P.M		564'				
8:00 PM	700	564'			54°F	
8:30 PM	700	566'	D.D. - 104'			6.7 GPM/ft. D.D.
9:00 PM	700	569'		7		
9:30 PM	700	572'				

SHAWVER WELL COMPANY, INC.

TEST PUMPING REPORT

Project:	Nevel Properties - Agri-Processors	Well ID:	No. 3
Location:	Postville, IA	Date:	5/17/2006

Time	GPM	PWL (air)	PWL (elec.)	Ph	Temp	Character of Water/Pumping Details
10:00 PM	700	572'				
10:30 PM	700	573'				
11:00 PM	700	574'				
12:00 AM	700	574'				
1:00 AM	700	574'				
2:00 AM	700	575'				
3:00 AM	700	576'		7		
4:00 AM	700	578'				
5:00 AM	700	578'				
6:00 AM	700	578'			54°F	
7:00 AM	700	578'				
8:00 AM	700	578'	D.D. - 116'			
9:00 AM	700	578'				
10:00 AM	700	578'	64 PSI			
11:00 AM	700	578'	AMPS 210, 212, 220			
12:00 PM	700	578'				
1:00 PM	700	578'				
Shut Off						
1:01 PM	76	566'				
1:02 PM	88	554'				
1:03 PM	110	532'				
1:04 PM	136	506'				
1:05 PM	152	490'				
1:06 PM	152	490'				
1:07 PM	148	494'				
1:08 PM	149	493'				
1:09 PM	149	493'				
1:10 PM	150	492'				
1:15 PM	152	490'				
1:20 PM	154	488'				