

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

Customer Water Works / MSA City Delmar, Iowa
Location West on Highway 136 Well No. 3
Size Casing 8" Total Depth 1225 Construction Steel
Make Pump Crown Model No. 5CH 225 No. of Stages 18
Diameter 5 Total Setting 462 Air Line Length 462
Meter Used 4" Static Level 312

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
2-7-06	12:00 pm	180	312	0	0	20	Clearing 64"
	12:01	180	363	51	3.52	20	Clear
	12:02	180	369	57	3.15	20	Clear
	12:03	180	374	62	2.9	18	Clear
	12:04	180	383	71	2.5	18	Clear
	12:05	180	400	88	2.0	15	Clear
	12:06	180	409	97	1.85	15	Clear
	12:07	180	414	102	1.76	15	Clear
	12:08	180	422	110	1.6	15	Clear
	12:09	180	430	118	1.52	15	Clear
	12:10	180	436	124	1.45	15	Clear
	12:11	180	440	128	1.4	15	Clear
	12:12	180	444	132	1.36	15	Clear
	12:13	180	449	137'	1.31	13	Clear
	12:14	180	456	144	1.25	10	Clear
	12:15	180	460	148	1.21	10	Clear
	12:20	160	458	146	1.09	10	Clear
	12:25	150	455	143	1.04	8	Clear
	12:30	150	451	139	1.07	8	Clear
	12:35	150	451	139	1.07	8	Clear
	12:40	150	451	139	1.07	8	Clear
	12:45	150	451	139	1.07	8	Clear
	12:50	150	452	140	1.07	8	Clear
	12:55	150	452	140	1.07	8	Clear
	1:00	150	455	143	1.04	8	Clear
	1:05	150	452	140	1.07	8	Clear
	1:35	150	449	137'	1.09	8	Clear

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

PAGE -2-

Customer Water Works / MSA City Delmar, Iowa
Location West on Highway 136 Well No. 3

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
2-7-06	2:05	150	449	137	1.09	8	Clear 64°
	2:35	150	449	137	1.09	8	Clear
	3:05	150	449	137	1.09	8	Clear
	3:35	150	449	137	1.09	8	Clear
	4:05	150	449	137	1.09	8	Clear
	4:35	150	449	137	1.09	8	Clear
	5:05	150	449	137	1.09	8	Clear
	5:35	150	449	137	1.09	8	Clear
	6:05	150	449	137	1.09	8	Clear
	6:35	150	449	137	1.09	8	Clear
	7:05	150	449	137	1.09	8	Clear
	7:35	150	449	137	1.09	8	Clear
	8:05	150	449	137	1.09	8	Clear
	8:35	150	449	137	1.09	8	Clear
Gated	9:00	120	438	126	.09	30	Clear
	9:05	120	427	115	1.04	30	Clear
	9:10	120	418	106	1.13	30	Clear
	9:15	120	412	100	1.2	30	Clear
	9:20	120	412	100	1.2	30	Clear
	9:25	120	412	100	1.2	30	Clear
	9:30	120	412	100	1.2	30	Clear
	9:45	120	412	100	1.2	30	Clear
	10:00	120	412	100	1.2	30	Clear
Recovery	10:01	OFF	359				
	10:05		320				
	10:15		318				
	10:30		314				
	10:45		312	Recovered			