

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

Customer City of Ankeny City Ankeny, Iowa
Location Otter Creek Golf Course Well No. ASR No. 2
Size Casing 24" Total Depth 2526' Construction Jordan
Make Pump Verti-Line Model No. 14RH No. of Stages 8
Diameter 14" Total Setting 634' Air Line Length 634'
Meter Used 12" Propeller Static Level 363' From The Top of the Pitless Unit

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	Water Description
08/04/08	3:00 Pm		354'				
Pumping	3:01-3:05	2400	550'	196'			Some turbidity
Develop	3:10	2400	630'	276'			Clearing
	3:15	1400	616'	262'			Reduced Flow
	3:30	1400	616'	262'			
	3:45	1400	616'	262'			
	3:00	1400	616'	262'			Clear
Surging	3:01	2400	630'				
	4:00	1400	616'	262'			Some turbidity
	4:30	1400	616'	262'			Clear
Surging	4:30-5:00	2400	630'				
	5:00	1400	616'	262'			Some turbidity
	5:30	1400	616'	262'			
	6:00	1400	616'	262'			Clear
08/05/08	6:30 AM	1400	616'	262'			Clear
	7:00	1400	616'	262'			
	7:30	1400	616'	262'	5.34		
10/27/08	10:30 AM		368'SL				
Pumping	10:31	2800	550'	182'			Some turbidity
Develop	10:05	2800	555'	187'	15.38		
	10:30	2800	555'	187'	14.97		Clear
	10:35	2100	545'	177'			
	10:45	2100	503'	135'			
	11:00	2100	495'	127'	16.53		
	11:30	2100	495'	127'	16.53	Can not	Get rid of 2100 gpm
Surged	12:00-1:	1700					Cloudy
	1:00 PM	1700	470'	102'	16.66		Clear
	1:30	1700	470'	102'	16.66		
	2:00	1700	470'	102'	16.66		

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

Customer City of Ankeny City Ankeny, Iowa
Location Otter Creek Golf Course Well No. ASR No. 2
Size Casing 24" Total Depth 2526' Construction Jordan
Make Pump Verti-Line Model No. 14RH No. of Stages 8
Diameter 14" Total Setting 634' Air Line Length 634'
Meter Used 12" Propeller Static Level 368' From The Top of the Pitless Unit

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	Water Description
10/28/08	5:00 PM	2100	368'				
	5:01	2100	459'	91'	23.07		Clear
	5:02	2100	474'	106'	19.81		
	5:03	2100	479'	111'	18.92		
	5:04	2100	480'	112'	18.75		
	5:05	2100	481'	113'	18.58		
	5:10	2100	484'	116'	18.10		
	5:15	2100	486'	118'	17.80		
	5:20	2100	487'	117'	17.94		
	5:25	2100	490'	122'	17.21		
	5:30	2100	493'	125'	16.80		
	5:45	2100	494'	126'	16.66		
	6:00	2100	495'	127'	16.53	90	Sand Free
	7:00	2100	495'	127'	16.53		
	8:00	2100	495'	127'	16.53		
	9:00	2100	495'	127'	16.53		
	10:00	2100	495'	127'	16.53		
	11:00	2100	495'	127'	16.53		
	12:00 AM	2100	495'	127'	16.53		
	1:00	2100	495'	127'	16.53		
	2:00	2100	495'	127'	16.53		
Recovery	2:01		459'				
	2:02		442'				
	2:03		433'				
	2:04		414'				
	2:05		395'				
	2:10		382'				
	2:15		371'				
	2:20		368'				

4895. 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

**100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575**

PAGE -2-

Customer City of Ankeny City Ankeny, Iowa
Location Otter Creek Golf Course Well No. ASR No. 2

[illegible]