




# HOEG & AMES, Inc.

WELL CONTRACTORS

WELL SUPPLIES

☆☆☆

LINCOLN, IOWA



PUMPING RECORD - RUDD, IOWA - SEPTEMBER 22, 1958

<u>TIME</u>	<u>WATER LEVEL</u>	<u>GAL. PER MIN.</u>	<u>REMARKS</u>
10:15 A.M.	171		Started pump
10:20	183	280	
10:25	183		
10:30	183		Water clearing
10:45	183		
11:00	183		
11:30	183	280	Water clear
12:00 P.M.	183		Engineer took water sample
12:30	183		
1:00	183	280	Water clear speed up pump
1:05	190	360	
1:15	190		
1:30	190		Water cloudy
2:00	190	360	Water clear
2:30	190		
3:00	190	360	Water clear. Slowed pump
3:05	184	294	
3:10	184		Slowed pump
3:15	182		
3:30	182	265	Water clear
4:00	182		
4:30	182		
5:00	182	265	
5:30	182		Caught water sample
6:00	182		
6:15	182		Shut pump off

D.D. 12'

D.D. 19'