

NORTHWAY WELL AND PUMP COMPANY

4895 8th Avenue
Marion, Iowa 52302
319-377-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575

WELL TEST DATA REPORT

Customer Rockwell City City Rockwell City, Iowa
Location At New Water Tower Well No. 6
Size Casing 16 & 10 Total Depth 1970' Construction _____
Pump Make MidAmer (Layne) Model No. 9-12 THC LOM No. of Stages 9
Diameter 12" Total Setting 428' Air Line Length 428'
Meter Used Propeller Static Level 208'

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP. DISCHARGE DESCRIPTION
8-26-04	6:15am					65	
	6:16	1750	298'	90	19.44		Clear
	6:17	1750	304'	96	18.22		No Sand
	6:18	1750	305'	97	18.04		
	6:19	1750	306'	98	17.86		
	6:20	1750	308'	100	17.5		
	6:21	1750	308'	100	17.5		
	6:22	1750	308'	100	17.5		
	6:23	1750	308'	100	17.5		
	6:24	1750	309'	101	17.33		
	6:25	1750	309'	101	17.33		
	6:30	1750	310'	102	17.15		
	6:35	1750	311'	103	16.99		
	6:40	1750	311'	103	16.99		
	6:45	1750	312'	104	16.82		
	7:00	1750	313'	105	16.66		
	7:15	1750	313'	105	16.66		
	7:30	1750	313'	105	16.66		
	7:45	1750	314'	106	16.51		
	8:00	1750	315'	107	16.35		
	8:30	1750	317'	109	16.05		
	9:00	1750	317'	109	16.05		Sand Test
	9:30	1750	318'	110	15.91		No Sand
	10:00	1750	318'	110	15.91		
	11:00	1750	319'	111	15.76		
	12:00pm	1750	320'	112	15.62		
	1:00	1750	322'	114	15.35		

100 North 6th Street
Waukec, Iowa 50263
515-987-4575

[illegible]