

PUMPING TEST ON WELL NO. 1 - June 11, 1957

<u>TIME</u>	<u>DRAWDOWN</u>	<u>WATER LEVEL</u> OR <u>PUMPING LEVEL</u>	<u>GAL. PER MIN.</u>	<u>REMARKS</u>
7:50 A.M.		7'ft. 6 in.		Started pump
7:55	58	65-6	175	Dirty
12:45 P.M.	58	65-6	175	Water clear.
				Slowed pump
1:15	26 - 6	34	140	
1:30	26 - 4	33-8		
2:00	26 - 4	33-8	135	
2:30	26 - 11	34-5	140	
3:00	25 - 7	33-1		Shut off City pump
3:30	25 - 7	33-1	140	Started City pump
4:00	26	33-6	140	Shut pump off

16 in. hole
66 ft. deep
Drilled into limestone

This pump test was conducted June 11, 1957

Bert B. Hanson, City Engineer officiating.