



MAIN OFFICE: LINCOLN, IOWA 50652
PHONE 515/473-2707



WE GUIN THE WELL - CHANGE MINDS

1310 HAMMOND AVE. • WATERLOO, IOWA 50602
PHONE 319-233-2285

036432

Production Well at Test Hole Site #2
RECORD OF WELL

Owner Town of Beaman

Address Beaman, IA 50609

Tenant

Address

Location North end of town just North of Water Tower NE $\frac{1}{4}$
. of the NW $\frac{1}{4}$ of Section 34 in Clay Township in Grundy
. County. T86N R17W

Started the Well November 20, 1978

Finished the Well December 14, 1978

Total Depth 125' Size of Well 8"

Static Water Level 78' 4"

Draw-down 30' 4" feet, pumping 63 Gal. P.M.
. 53 feet of 8 inch pipe installed
. 78 $\frac{1}{2}$ feet of 7 O.D. inch casing installed

Driller Alfred Harris, III

Remarks Drilled 12" hole to 53' Set 8" pipe in center
. and cement grouted between the 8" pipe and the 12" hole We
. then acidized the well with 182 gallons of Muriatic Acid

FORMATION

0 - 50	Drift
50 - 120	Limestone
120 - 125	Shale

Beaman City Well

