

WELL PRODUCTION TEST DATA SHEET

Job Town of Beaman Date Tested 12/16/78 & 12/17/78
 Location North end of town by water tower Tested by Howard M. White
 Diameter of Well 8" Pump Used Line-Shaft Turbine
 Depth of Well 125' Driver Diesel
 Length of Airline Electric Probe Col. & Shaft 4 X 1
 Static W. L. 48' Bowls 6"
 Orifice Size 3 X 6 Mfr. --

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW-DOWN	REMARKS
11:10 A.M.						Started pump.
11:11	5"	77	53'	48'	5'	
11:13	5"	"	55' 6"	"	7' 6"	Checked well with a 60
11:16	5"	"	57'	"	9'	gallon tank. Fills in
11:20	5"	"	58' 4"	"	10' 4"	47 seconds.
11:26	5"	"	59' 9"	"	11' 9"	
11:30	5"	"	60'	"	12'	
11:34	5"	"	60' 3"	"	12' 3"	
11:38	5"	"	60' 5"	"	12' 5"	
11:40	5"	"	60' 9"	"	12' 9"	
11:50	5"	"	62'	"	14'	
12:00 P.M.	5"	"	63'	"	15'	Clearing
12:15	5"	"	64'	"	16'	
12:30	5"	"	65' 5"	"	17' 5"	
12:45	5"	"	66' 6"	"	18' 6"	
1:00	5"	"	67' 4"	"	19' 4"	
1:30	5"	"	69'	"	21'	

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
 Location _____ Tested by _____
 Diameter of Well _____ Pump Used _____
 Depth of Well _____ Driver _____
 Length of Airline _____ Col. & Shaft _____
 Static W. L. _____ Bowls _____
 Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW-DOWN	REMARKS
2:00 P.M.	5"	77	69' 10"	48'	21' 10"	
2:30	4 1/4"	72	69' 7"	"	21' 7"	Tank fills in 50 seconds
3:00	4 1/4"	"	69' 9"	"	21' 9"	
3:30	4 1/4"	"	69' 11"	"	21' 11"	
4:00	4 1/4"	"	70' 2"	"	22' 2"	
4:30	4"	"	70' 5"	"	22' 5"	
5:00	4"	"	70' 7"	"	22' 7"	
5:30	4"	"	70' 11"	"	22' 11"	
6:00	4"	"	71' 1"	"	23' 1"	
6:30	4"	"	71' 5"	"	23' 5"	
7:00	4"	"	71' 9"	"	23' 9"	
7:30	4"	"	72'	"	24'	
8:00	4"	"	72' 2"	"	24' 2"	
8:30	4"	"	72' 5"	"	24' 5"	
9:00	4"	"	72' 7"	"	24' 7"	
9:30	3 3/4"	69	72' 8"	"	24' 8"	Tank fills in 52 seconds
10:00	"	"	73' 2"	"	25' 2"	

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
 Location _____ Tested by _____
 Diameter of Well _____ Pump Used _____
 Depth of Well _____ Driver _____
 Length of Airline _____ Col. & Shaft _____
 Static W. L. _____ Bowls _____
 Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW-DOWN	REMARKS
10:30 P.M.	3 3/4"	69	73' 3"	48'	25' 3"	
11:00	"	"	73' 3"	"	25' 3"	
11:30	"	"	73' 5"	"	25' 5"	
12:00 A.M.	"	"	73' 6"	"	25' 6"	
12:30	"	"	73' 7"	"	25' 7"	
1:00	"	"	73' 8"	"	25' 8"	
1:30	"	"	73' 9"	"	25' 9"	
2:00	"	"	73' 10"	"	25' 10"	
2:30	"	"	74' 3"	"	26' 3"	Water Very Dirty
3:00	"	"	75' 8"	"	27' 8"	
3:30	"	"	75' 9"	"	27' 9"	Clearing
4:30	"	"	76' 4"	"	28' 4"	
5:30	"	"	76' 10"	"	28' 10"	
6:30	"	"	77' 5"	"	29' 5"	
7:30	"	63	78'	"	30'	Tank fills in 57 seconds
8:30	"	"	78' 1"	"	30' 1"	Water Clear
9:30	"	"	78' 2"	"	30' 2"	Tank fills in 57 seconds

WELL PRODUCTION TEST DATA SHEET

Job _____ Date Tested _____
 Location _____ Tested by _____
 Diameter of Well _____ Pump Used _____
 Depth of Well _____ Driver _____
 Length of Airline _____ Col. & Shaft _____
 Static W. L. _____ Bowls _____
 Orifice Size _____ Mfr. _____

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W. L.	DRAW-DOWN	REMARKS
10:30	3 3/4"	63	78' 2"	48'	30' 2"	Test hole #4 water level
11:10	"	"	78' 4"	"	30' 4"	@ 10:50 is 62'
11:17	"	"	78' 4"	"	30' 4"	Stopped pump
11:18				73' 6"		
11:19				72'		
11:22				71' 6"		
11:27				71'		
11:34				70' 9"		
11:40				70' 1"		
11:50				69' 3"		
12:05 P.M.				68' 4"		
12:30				67' 2"		
12:45				66' 8"		
1:00				66' 4"		
1:17				66' 2"		