

WELL TEST DATA SHEET



Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

Job Town of Stockport..... Well no..... Date Tested 6-8-72
 Location Stockport, In.
 Dia of Well 10 to 6 to 8 3/4 open hole
 Depth of Well 1880 Pump Used: Column and Shaft.....
 Length of Airline 250 Bowls 15 stage URHC
 Non-Pumping Level 197 ft. 122.5 Manufacturer Layne
 Orifice Size 4 to 3 Serial No.....

After Acidizing

Time	Piezometer Reading (in.)	G. P. M.	Air Gauge Reading (feet)	Pumping Level	Drawdown	Disch. Pressure		Total Pumping Head	Remarks
						Lbs.	Feet		
		SWL	53						
7:30	8½	125	23	227	30	3			
7:31	8½	125	22	228	31	3			
7:32	8½	125	12	238	41	3			
7:33	6	108	10	240	43	3			
7:35	6	108	8	242	45				
7:40	4	75	16	234	37				
7:45	5½	104	8	242	45				
7:50	5½	104	8	242	45				
7:55	5½	104	7	243	46				
8:00	5½	104	7	243	46				
8:15	5½	108	14	236	39				
8:30	5½	104	14	236	39				
8:45	5½	104	14	236	39				
9:00	5½	104	10	240	43				
9:15	5½	104	10	240	43				
9:30	5½	104	10	240	43				
9:45	5½	104	10	240	43				
10:00	5½	104	10	240	43				
10:30	5½	104	9	241	44				
11:00	5½	104	9	241	44				
11:30	5½	104	9	241	44				
12:00	5½	104	9	241	44				
<i>specific capacity 2.3</i>									

Layne-Western Company, Inc.

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

A-716

Job Stockport, Iowa Well no. Date Tested 4-7-72

Location.....

Tested By.....H. Beal.....

Dia. of Well...10" to 260' then 6".....

Driver International engine.....

Depth of Well.....

Pump Used:

Column and Shaft 4" x 1" - 245'

Length of Airline.....245'

Bowls 8" URHC, 15 stages

Non-Pumping Level...205!

Manufacturer Layne

Orifice Size 3" on 4" pipe

Serial No. 21563A.....

[illegible]