

WELL RECORD

RECORD OF PERMANENT CASING

Well is located.....miles S and.....miles S from
N E
E E
W W

Eldridge in *Scott*,
(Nearest Town) (County)

in the 1/4 1/4 Sec. T. R.

Owner *Town of* Well No. *3*

Postoffice address *Eldridge*

Contractor *L. F. Winslow*

Address *Walcott*

Driller *L. F. Winslow*

Well begun *Sept 1*, 19*55*;

completed *Nov 22*, 19*55*

Rig used—Cable, Rotary, Jet, or *Cable*

Depth of well *487*
(Feet)

Size of hole (note total amount of each size).....

Main water supply at *210 to 400 ft*
(Feet below surface)

Final water head *87 ft*
(Feet above or below surface)

Is well pumped? *5 hrs*

Yield *275 gal per min*
(Gallons per minute)

Water level when pumping *105*

Position of well *✓*
(Upland, valley, side hill, etc.)

Size Pipe	Amount of Pipe	Depth to Bottom of Pipe	Depth to Top of Pipe	Type* and Weight of Pipe	DIAGRAM OF WELL
<i>18"</i>	<i>102 pipe</i>			<i>steel</i>	
	<i>208 pipe</i>			<i>15.4</i>	

*As cast, wrought iron, steel, concrete, etc.

Is screen used?..... Diameter.....
(Inches)

Length..... Depth to bottom.....
(Feet)

Depth to top..... Slot size.....

Are packers or seals used?.....

Kind

Where used.....

Kind of pump..... Dia.....
(Inches)

Capacity of pump.....
(g.p.m.)

Power used.....
(Kind and amount)

Depth to bottom of pump line..... feet,
including feet tailpiece.

Remarks on construction of well.....

Sample No.	DEPTH		THICKNESS
	From	To	
1	0	5	
2	5	10	
3	10	15	
4	15	20	
5	20	25	
6	25	30	
7	30	35	
8	35	40	
9	40	45	
10	45	50	
11	50	55	
12	55	60	
13	60	65	
14	65	70	
15	70	75	
16	75	80	
17	80	85	

DESCRIPTION OF BEDS

KIND OF ROCK, COLOR, HARD OR SOFT, WATER, ETC.

Black dirt
 yellow clay
 Blue mud
 Blue mud
 Blue mud
 Blue clay
 Blue clay
 Blue clay
 Blue clay and sand
 Blue clay and sand
 Blue clay and sand
 Blue clay and sand
 Blue clay and sand
 Blue clay and sand
 Blue clay and sand
 Yellow clay and sand
 yellow clay and sand

Sample No.	DEPTH		THICKNESS
	From	To	
18	85	90	
19	90	95	
20	95	100	
21	100	105	
22	105	110	
23	110	115	
24	115	120	
25	120	125	
26	125	130	
27	130	135	
28	135	140	
29	140	145	
30	145	150	
31	150	155	
32	155	160	
33	160	165	
34	165	170	

[illegible]

Sample No.	DEPTH		THICKNESS
	From	To	
35	170	175	
36	175	180	
37	18 0	18 5	
38	18 5	19 0	
39	19 0	19 5	
40	19 5	200	
41	20 0	20 5	
42	20 5	21 0	
43	21 0	21 5	
44	21 5	22 0	
45	22 0	22 5	
46	22 5	23 0	
47	23 0	23 5	
48	23 5	24 0	
49	24 0	24 5	
50	24 5	25 0	
51	25 0	25 5	

[illegible]

Sample No.	DEPTH		THICKNESS.
	From	To	
51	250	255	
52	255	260	
53	260	265	
54	265	270	
55	270	275	
56	275	280	
57	280	285	
58	285	290	
59	290	295	
60	295	300	
61	300	305	
62	305	310	
63	310	315	
64	315	320	
65	320	325	
66	325	330	
67	330	335	

[illegible]

