

58045

MID-AMERICA DRILLING CORP.

P.O. BOX 399

OAKLAND, IOWA 51560

PHONE 712-482-6911

FAX 712-482-3366

Sept. 24, 2003

City of Carson, IA

Pumping Test Results

Well Depth 155'

Screen Depth 145' - 155'

Static Water Level 117'3"

Time	Water Level	Existing Well
7:30AM	117'3"	
7:31	131	
7:32	134' 5"	
7:33	136'5"	
7:34	137'8"	
7:35	138'5"	
7:40	139'11"	
7:45	140'7"	
7:50	140'10"	
7:55	140'11"	
8:00	141'	
8:05	141'2"	
8:10	141'3"	
8:15	141'6"	
8:20	141'7"	
8:25	141'8"	
8:30 (1 hour)	141'9"	
8:50	142'	
9:10	142'4"	
9:30	142'6"	
10:00	142'9"	
10:30	143'	
11:00	143'3"	
12:00 P.M.	143'6"	
1:00	143'7"	
2:00	143'9"	127'6"
3:00	144'	

MID-AMERICA DRILLING CORP.

P.O. BOX 399

OAKLAND, IOWA 51560

PHONE 712-482-6911

FAX 712-482-3366

Time	Water Level	Existing Well
4:00	144'3"	
5:00	144'6"	128'2"
6:00	144'8"	
7:00	144'10"	
8:00	145' (Note: Top of screen)	
9:00	145'1"	
10:00	145'2"	
11:00	145'3"	
12:00 A.M.	145'5"	
1:00	145'7"	
2:00	145'9"	
3:00	145'11"	
4:00	146'1"	
5:00	146'1"	
6:00	146'1"	
7:00	146'2"	130'9"
7:30	146'2"	
7:30 (stop pump) Recovery Time		
7:31	141'6"	
7:32	132'	
7:33	127'6"	
7:34	126'2"	
7:35	125'3"	
8:00	122'2"	
9:00	121'	121'3"
10:00	120'3"	
12:30	120'	
1:30	119'9"	
2:30	119'7"	
3:30	119'5"	
5:30	119'2"	