

New Town Well at Woodbine, Harrison Co.

Pumping Test

Test started at 1:35.

Static water level = 12 ft

Time	Flow meter readings in gallons	G.P.M. obtained by timing flow meter	Water level below curb in feet
1:35	11197100	170	12
2:15	11202600	170	45
3:15	11212600	200	46
4:15	11202800	Stop	50
5:15	11232700	200	50
6:15	11242200		50
7:15	11254100		52
9:15	11278100		52
10:15	11289100		53
11:15	11300500		
12:15	11312600		
1:15	11323700		
2:15	11335300	200	
3:15	11347400		
4:15	11359200		
5:15	11370800		
6:15	11382700		
7:15	11395100		
9:15	11418000		
11:15	11442700		57
12:15	11452400		57

Data obtained from Mr. M.E. Hill, Water Supt. of Woodbine. No figures on recovery.