

12. Pumping test — measurements from ground level:

TIME	G.P.M.	STATIC	DRAWDOWN	PUMPING LEVEL
1:00	225	11'	29'	40'
1:30	225	11'	30'	41'
2:00	225	11'	31'	42'
3:00	225	11'	31'	42'
4:00	225	11'	31'	42'
5:00	225	11'	31'	42'
6:00	300	11'	45'	56'

13. Recovery in 5 minutes..... **back to 24'**, in 30 minutes.....