

Layne-Western Company

4430 Commercial Avenue - Omaha, Nebraska

19903

TEST WELL REPORT

City and State **Hinton, Iowa** Date **September 22, 1966**

Contract **City of Hinton, Iowa** Driller **Dell Hasic**

Test No. **66-1** Helpers **Einer Pedersen**

Static Water Level

Test Log

0'	- 15'	Black gumbo clay-like soil
15'	- 19' 6"	Coarse sand and gravel
19' 6"	- 20'	Clay
20'	- 30'	Coarse sand and gravel
30'	- 33'	Coarse sand, gravel, and boulders
33'	- 51'	Blue clay

Size Mud Pit—Length , Width **3'** , Depth

WATER BEARING FORMATION DATA

Depth	Mud Viscosity	Inches Mud Taken from Pit	Drilling Time
to			
20 to 30	52 Sec.		
to			
to			
to			
to			
to			

LOCATION: **156' east from center line of Center Street**

REMARKS: **179' north from center line of Main Street
7' 6" south from north property line**