

#29454

Date 11-15-66

Griffin Dewatering.

2

1-A

Contractor: City of Okaloosa Fla.Rig No.: 1-AJob Address: 3 mi NW OkaloosaJob No.: City Well

Job Phone: _____ Comments: _____

Driller: David LaneBranch No.: CherokeeNo. of wells installed today: 1Depth of hole: 57'Dia of borehole: 38"

Length of well: _____

Dia. of well: 20" (CASING: 0.375" wall)Length of screen: 15'5"Type, dia., slot of screen Johnson SS-60.000

Well yield: _____

Travel Hours 0 Stand by Hours 0Revert used: 0Man Hours Regular: 8 Drill Hours Reg.: 8Total footage drilled today: 57'Overtime: 2 O.T.: _____Delays-Explain: 26'-36' Slow Drilling Delay Hours: 45 min. BouldersRain Very Hard Starting at 4:15 pm workeduntil 5:00 pm.

Mileage				
State				

Fuel Supplied By: (check one)

☒ Driller☐ Contractor

S. ELEV. 89.8

WELL LOG

Depth	Formation	Depth	Formation
0-5	Firm Brown Clay		
5-10	Silty light clay		
10-15	Sandy gray clay		
15-17	Sand and "water level"	17'	
17-20	Fine sand		
20-21	Blue clay - hard		
21-26	Medium to coarse sand		
26-31	Cobbles, gravel, pebbles		
31-36	Coarse gravel + cobbles		
36-41	Medium to coarse gravel		
41-46	Medium to coarse gravel		
46-51	Coarse gravel		
51-56	Coarse gravel		
56-57	Gravel plastic clay		
57'	T.D. Bed Rock		

David Lane
Driller

Shirley R.
Verified Contractor