

Shawver

Well Company, Inc.



BOX 266 FREDERICKSBURG, IOWA • 50630
319/237-5341

May 1, 1989

Silvercrest Country Club
Decorah, IA 52101

LOG OF WELL

0'	to	30'	Brown clay
30'	to	190'	Limerock
190'	to	265'	Shale and limerock
265'	to	337'	Sandstone
337'	to	338'	Shale
338'	to	395'	Limerock
395'	to	415'	Sandstone
415'	to	481'	Limerock
481'	to	485'	Open crevice
485'	to	537'	Limerock
537'	to	538'	Sandstone
538'	to	656'	Limerock
656'	to	678'	Sandstone and limerock
678'	to	695'	Limerock
695'	to	755'	Sandstone
755'	to	765'	Gray limerock

The well is cased to 363'6" with 8" I.D. x .322 wall steel casing.
A 13" hole was drilled to 361' and 230 sacks of cement grout
pumped in the annular space.

The static water level is 260'.

The recommended pump setting is 350'.