

6/29/87

test hole #
Orange City #4 Municipal Well
Orange City

Sioux County West Branch Twp. Sect. 28

8" Black pipe & 8" S.S. Screen from 26' to 41'

0-10 top soil - sandy silt

10-37 yellow sand & gravel

37-40 1/2 green sand & gravel

40 1/2- boulders - cobbles & gravel

WLFS 8' pumping level @ 23'-7"

@ 157 Gpm after 24 hrs of pumping