

IOWA GEOLOGICAL SURVEY

123 North Capitol St.
Iowa City, Iowa 52242
Phone (319) 338-1173



32142

JOB _____ WELL NO. 2 DATE TESTED 10/24/90
 LOCATION ATALISSA, IA TESTED BY DON LATTA
 Diameter of Well 8" Pump Used: _____ Driver 24HP SUB
 Depth of Well _____ Column & Shaft _____
 Length of Airline 336' Bowls _____
 Non-Pumping Level 100.38' Manufacturer _____
 Orifice Seize _____ Serial No. _____

Date and Time	Time Accumulative	Piezometer Reading	G.P.M.	Air Gauge Reading (ft.)	P.W.L. (feet)	Drawdown (feet)	Remarks
9:29	0		0	102-PSI	100.38'		
9:31	1		220	75	163		
9:32	1		220	72	170		
9:33	1		220	70	174		
9:34	1		220	70	174		
9:35	1		220	70	174		
9:40	5		220	68	179		
9:45	5		220	65	186		
9:50	5		220	65	186		
9:55	5		220	65	186		
10:00	5		220	65	186		
10:15	15		220	63	191		
10:30	15		220	63	191		
10:45	15		220	61	196		
11:00	15		220	62	193		
11:30	30		220	62	193		
12:00	30		220	62	193		

