

TO: Mr. Bob Wolf  
2920 Industrial Park Road  
Iowa City, Iowa 52244

RE: Well Log  
#2 Well - By Pump House  
Modern Manor Mobile Home Court - Scott Blvd.

| <u>Depth</u>                                      | <u>Description of Beds</u>        |
|---------------------------------------------------|-----------------------------------|
| 0' - 6'                                           | Yellow clay                       |
| 6' - 22'                                          | Sand - gray clay                  |
| 22' - 27'                                         | Gray clay                         |
| 27' - 46'                                         | Peat                              |
| 46' - 63'                                         | Gray clay                         |
| 63' - 83'                                         | Gray sand                         |
| 83' - 103'                                        | Gray clay                         |
| 103' - 118'                                       | Gray clay - streaks of sand       |
| 118' - 150'                                       | Shale - streaks rock - rock dough |
| 150' - 163'                                       | White brown lime                  |
| 163' - 230'                                       | Gray lime                         |
| 230' - 243' 10"                                   | Brownish white lime               |
| { Casing set to 243' 10" - cemented bottom to top |                                   |
| 243' 10" - 292'                                   | Brownish white lime               |
| 292' - 324'                                       | Gray lime                         |

*Handwritten notes:*  
- "should" with arrow pointing to "Gray clay" at 22'-27'  
- "sand, clay" next to "Sand - gray clay"  
- "shale" next to "Shale - streaks rock - rock dough"  
- "this is the" next to "Gray lime" at 163'-230'

Casing 7" O.D. steel casing  
SWL Static water level - 30'  
PWL Test pumped 100 gpm @ 150'  
Cemented bottom of casing to top  
DRILLER: LATTA WELL & PUMP  
R. #2  
WILTON, IOWA 52778

cc: M.M.S. Consultants