

BREMER CO. CONSV. OFFICE  
Main Street  
Tripoli, Iowa

W-36556

A  
Bremer, Frederika, Sec. 7 NW $\frac{1}{4}$  SW $\frac{1}{4}$   
June 16, 1983  
Alcock Park, Frederika

LOG OF WELL

|     |    |     |                  |
|-----|----|-----|------------------|
| 0'  | to | 2'  | Topsoil          |
| 2'  | to | 15' | Sand             |
| 15' | to | 26' | Limerock (water) |
| 26' | to | 40' | Gray limerock    |
| 40' | to | 60' | Limerock         |

The well is cased to 20' with 5" I.D. x .275 P.E. casing. An 8" hole was drilled to 16' and cement grout installed in the annular space.

The static water level is 7'.

The recommended pump setting is 40'.

BUTCH

ALCOCK PARK

W-36556

Bremer, Frederika, Sec. 7 NW $\frac{1}{2}$  SW $\frac{1}{2}$

Bremer Co. Consv. Office June 16, 1983

Tripoli, Iowa

LOG OF WELL

|     |    |     |                  |
|-----|----|-----|------------------|
| 0'  | to | 2'  | Topsoil          |
| 2'  | to | 15' | Sand             |
| 15' | to | 26' | Limerock (water) |
| 26' | to | 40' | Gray limerock    |
| 40' | to | 60' | Limerock         |

The well is cased to 20' with 5" I.D. x .275 P.E. casing. An 8" hole was drilled to 16' and cement grout installed in the annular space.

The static water level is 7'.

The recommended pump setting is 40'.

BUTCH