

Site Identification

Property Owner Open Bible Camp Well Number _____

Address 2387 242nd St Ventura Heights

Tenant Ventura IA 50482

Well Depth 215 ft. Date Completed 7 / 27 / 95


Location

County Cerro Gordo


Well is 1/2 mi. ^N and 1/2 mi. ^E of intersection of 18 and 145

N/E 1/4 of the N/E 1/4 of the SW 1/4 of Sec 20 TWP 96N RNG 22 ^E_W

Show exact location of well in section grid with a dot (•).



Sketch Map of Well Location
(Indicate North)



Formation Log

From	To	Color	Hardness	Description
0	10	Brn	soft	Topsoil / Clay
10	15	Tan	soft	Clay.
15	65	Blw	soft	Clay
65	77	Tan	soft	Clay
77	106	Blw	soft	Clay
106	117	Tan	soft	Clay
117	140	Grey	soft	Clay
140	150	Grey	med	Rock
150	157	DKG.	med	Rock
157	160	Green	soft	Shale
160	160.5	Green	soft	Shale.
160.5	168	Wht	med	Rock
168	180	DKBrn	med	Rock
180	190	Grey	soft	Rock Water
190	195	Grey	Hard	Rock
195	198	Wht	Med	Rock Water
198	207	Tan	med	Rock Water
207	210	Green	med	Rock
210	215	Brn	Hard	Rock

use second sheet if needed

Remarks

(Topographic position, elevation, development, disinfection, water quality, etc.)

water 180' - 205' 27 bap
cement grout

Well Use

- ☐ Domestic ☐ Municipal ☐ Industrial
☐ Livestock ☒ Public Supply ☐ Monitoring
☐ Test Well ☐ Irrigation ☐ Other _____

Measuring Point (MP)

All depth measurements are made from:

- ☐ Ground Level ☐ KB/other 1 ft. (above/below) ground level

Hole Size

12 3/4 inch from 0 ft. to 148 ft. continued _____ inch from _____ ft. to _____ ft.
6 inch from 148 ft. to 215 ft. _____ inch from _____ ft. to _____ ft.

Casing

☒ ID / OD ? Drive shoe? ☒ (yes / no) Pitless adaptor? ☒ (yes / no)

Size	Type / Wt.	Depth Top	Depth Bottom	Amount (length)
6"		+2'	148'	148'

Perforated or Slotted Casing? (yes / no)

Perforated / Slotted from _____ ft. to _____ ft.

Perforated / Slotted from _____ ft. to _____ ft.

Casing Grouted? (yes / no)

☒ Neat Cement ☐ Bentonite ☐ other _____

from 0 ft. to 148 ft.

from _____ ft. to _____ ft.

Well Screen? (yes / no)

Diameter	Slot size	Depth Top	Depth Bottom	Amount	Type / Mfg.

Gravel packed? (yes / no) from _____ ft. to _____ ft.

Bottom capped? (yes / no) with _____

Seals / Packers? (yes / no) kind _____ depth _____ ft.

Water Information

Main water supply zone from 180 ft. to 205 ft.

Supply zone rock type (sand/gravel limestone sandstone)

Final water head (static water level) 70 ft. (below/above) the MP

Pumping water level 120 ft. below MP at yield of 30 GPM

Water quality tested? (yes / no) Date tested 6 / 27 / 95

Tested by _____

Parameters tested for : _____

Test results _____

Pump

Pump installed? ☒ (yes / no) Date _____ / _____ / _____

Type of pump _____ Manufacturer's name _____

Depth to intake _____ ft. Tail pipe? (yes / no) length _____ ft.

Pump diameter _____ inches Rated capacity _____ GPM

Contractor's name Beemer-Well Drilling Registration no. 40060

Address Rt1 Box 2 Fairmont Mn 56031

Driller's name Tim Kollasch Drill method (rotary / cable) _____