09-96-00255

Site identification Property Owner WINNEBAGO COUNCIL BSA Well Number				Drill method
				Hole size hole size continued
Address 2588 HAWITHORNE AVE WAVERLY				Hole size 12 4 inch from 0 ft to 45 ft 64 inch from 13 ft to 60 ft
Tenant				978 inch from 45 ft to 113 ftinch fromft toft
Well Depth 160 ft Date Completed 4 / 25 / 96				Record all depth measurements from ground level (GL). Use (+) for above GL measurements.
Location County BREMER				Casing Drive shoe (yes / no) Pitless adaptor (yes / no)
mi. N andmi. E of intersection ofand				Size (ID(OD) Type / Wt Depth top Depth bottom Amount (length)
SE 1/4 of the SE 1/4 of the SE 1/4 of Sec 19 TWP 91 RNG 13 E				7 Steel 72 113 115
			W	
Show exa	act location of	well in section gr	id with a dot (•).	
	N	T T	Sketch map of well location on property N	
L	++-			Perforated or slotted casing? (yes/no)
W E E				Perforated / slotted fromft toft
				Perforated / slotted fromft toft
		•		Casing grouted? (yes/no)
	S		200 ft	Type Depth Top Depth Bottom Amount
upland		□valley	Elevation (if known)	
From	tion log	Color Hard	dness Formation description	
A	35	0	7	Well screen? (yes/no)
35	44	Brown	Broken Limerodo	Diameter Slot size Depth Top Depth Bottom Length Material
44	65		Sholo	
65	70		Linerock	Bottom capped (yes/no) with
70	80		open broken Umerade	
80	109		Shale	Gravel packed (yes/no) fromft toft
109	190		Limerack	type amount
150	1600		Shale + Conurcel	Well developed? (yes/no)
	100			Explain
				Pump installed? (yes/no) Date//
				Installer's name
				Type of pump Depth to intakeft
				Pump diameter Rated capacityGPM
				Water information Aquifer: □ sand/gravel limestone □ sandstone
				Main water-supply zone fromft toft
				Final water level (static water level) 70 ft (below) above) GL.
				Pumping water level 100 ft below GL; tape airline E-line
	1017 1017 1017			At yield of 5 GPM; orifice volumetric estimate Date
		use additional sh	neets as needed	
Remarks (including depth of lost drilling fluids, materials, or tools)				Water quality test? (yes/no) Date tested// Tested by
				Test results_
Well use				Z1-0112000 0 -
Well use ☐ Municipal ☐ Industrial				Contractor ONWVER Welle, Inc.
☐ Livestock ☐ Public Supply ☐ Monitoring ☐ Test Well ☐ Irrigation ☐ Other ☐				Address Wedericks Durg, JA 50630
Test Well Imgation Other (explain)				Driller Deil Branden Eurg Certification no. 40120