WELL RECORD W-39195 Permit No.

Site identification	Drill method rotary auger cable other
Property Owner Howard Co. Cons. Well Number	Hole size hole size continued 10 216
Address Howard Co. Courthouse, Cresce	124 thich from 0 ft to 52 ft 64 inch from 149 ft to 360ft
Tenant attn: Harold Chapman	9% from 52 ft to 149 ftinch fromft toft
Well Depth 360 ft Date Completed 08 / 13 / 96	Record all depth measurements from ground level (GL). Use (+) for above GL measurements.
Location County Howard	Casing Drive shoe (yes / no) Pitless adaptor (yes / no)
	Size (ID(OD) Type / Wt Depth top Depth bottom Amount (length)
S W	The Steel +2' 149' 151'
SW)4 of the1/4 of the1/4 of Sec 34 TWP9N RNG [5]	
Show exact location of well in section grid with a dot (•).	
N Sketch map of well location on property N	
	Perforated or slotted casing?
	Perforated / slotted fromft toft
W E E	Perforated / slotted fromft toft
-1-1-	Occion avantado ()
	Casing grouted? (yes / no) Type Depth Top Depth Bottom Amount
S 200 ft	- Normand Jag Sacka
□ upland □ hillside □ valley Elevation (if known) Formation log	ible Dille
From To Color Hardness Formation description	Well screen? (yes/no)
1 50 Immit & mod	Diameter Slot size Depth Top Depth Bottom Length Material
50 122 limerock	
122 355 galena	
355 360 Shall Rock	Bottom capped (yes / no) with
as of a succession	Seals / Packers (yes / no) kind depthft
	Gravel packed (yes/no) fromft toft
	type amount
	Well developed? (yes) no)
	Explain ar 16PM at 340'
	Pump installed? (yes/no) Date//
	Installer's name
	Type of pump Depth to intakeft
	Pump diameter Rated capacityGPM
	Water information Aquifer: □ sand/gravel □ limestone □ sandstone
	Main water-supply zone fromft toft
	Final water level (static water level) 28 ft (below) above) GL.
	Pumping water level 200 ft below GL; tape airline E-line
	At yield of 7 GPM; orifice volumetric estimate Date
use additional sheets as needed	Water quality test? (yes/no) Date tested//
Remarks (including depth of lost drilling fluids, materials, or tools)	Tested by
	Test results
Well use	Chambre mall co
Well use Domestic	Contractor / Well CO.
☐ Livestock ☐ Public Supply ☐ Monitoring	Address trederick burg, JA 50050
☐ Test Well ☐ Irrigation ☐ Other (explain)	Drifter/ HI Brandenbutta Certification no. 40120