

DETAIL OF WELL CONSTRUCTION WELL NO. 2 CITY OF CORALVILLE, IOWA W-40560

LAYNE-WESTERN COMPANY, INC. - AMES, IOWA

JULY 1970

STATIC LEVEL: 75 FT. CAPACITY: 183 G.P.M. DRAWDOWN: 17 FT. PUMPING LEVEL: 92 FT.

GEOLOGICAL LOG

CONSTRUCTION DETAIL

