

DESIGN OF WELL CONSTRUCTION

WELL NO. 4
CORALVILLE, IOWA

W-40567

LAYNE-WESTERN COMPANY, INC. - AMES, IOWA

JULY 1972

STATIC LEVEL: 55 FT.

CAPACITY: 175 G.P.M.

DRAWDOWN: 8 FT.

PUMPING LEVEL: 63 FT.

GEOLOGICAL LOG

CONSTRUCTION DETAIL

