Site Identification	Well Use
Property Owner Jown of Ottosen Well Number 1-95	☐ Domestic ☐ Municipal ☐ Industrial
Address Ottosen Ja 505.39	☐ Livestock
Tenant	☐ Test Well ☐ Irrigation ☐ Other
Well Depth 106 ft. Date Completed 4 124 195	Measuring Point (MP) All depth measurements are made from: Ground Level KB/other ft. (above/below) ground level
Location County Humbold+	
Well ismi. N and In town of intersection of Cand Pao	Hole Size continued continued ft. to 114 ft. inch fromft. toft.
$\frac{SW}{1/4}$ of the $\frac{NE}{1/4}$ of the $\frac{SW}{1/4}$ of Sec $\frac{3}{3}$ TWP $\frac{93}{93}$ RNG $\frac{30}{8}$	inch fromft. toftinch fromft. toft.
Show exact location of well in section grid with a dot (•).	Casing (ID/OD)? Drive shoe? (yes/no) Pitless adaptor? (yes/no) Size Type / Wt. Depth Top Depth Bottom Amount (length)
N Sketch Map of Well Location (Indicate North)	5 PW 250 5 86 81
-+ Main SF	6 Steel 1 Above 5 6
W E N Moomm Twater Center Comm	
7 120 - weil	Perforated or Slotted Casing? (yes no)
S '	Perforated / Slotted fromft. toft.
Alley	Perforated / Slotted fromft. to ft.
Formation Log	
From To Color Hardness Description	Casing Grouted? (yes/no)
0 3 Black Soft Dirt	Neat Cement Bentonite
3 20 yellow" Clay	sent from / ft. to 5 ft.
20 55 Gray " Clay	Com from 5 ft. to 2 ft.
55 56 White Hard Rock	Well Screen? (yes)no)
56 65 Blue Soft Clay	Diameter Slot size Depth Top Depth Bottom Amount Type / Mfg
65 70 yellow " SandéClay	5 .018 86 106 20 55
70 114 yellow" Sand	
114- White Hall Pool	Gravel packed? (yes) no) from 106 ft. to 75 ft.
The Hara NOCK	Bottom capped? (yes/no) with Bra55 Plug
	Seals / Packers? (yes (no)) kind depthft.
	Water Information
	Main water supply zone from
	Supply zone rock type (sand/gravel, limestone, sandstone) Final water head (static water level)ft. (below / above) the MP
	Pumping water level 50 ft. below MP at yield of 80 GPM
	Water quality tested? (yes no) Date tested//
	Tested by
	Parameters tested for : Test results
	TOOL TOOURO
	Pump Pump installed? (yes/no) Date 5 / 20 / 95
	Pump Pump installed? (yes/no) Date 5 1 20 1 95 Type of pump Subm Manufacturer's name Aermotor
use second sheet if needed	Depth to intakeft. Tail pipe? (yes (no) lengthft.
Remarks (Topographic position, elevation, development, disinfection, water quality, etc.)	Pump diameter 33/4 inches Rated capacity 75 GPM
Flat land	Contractor's name Elbert Bros Well Registration no. 40130 Address Whittemore Ja 30598
	Address Williamore Jasos 78
	Driller's name Bill Elbert Drill method (rotary (cable)