

W43161

THORPE WELL COMPANY

2340 SIXTH AVENUE
DES MOINES, IOWA

THIS RECORD IS MICROFILMED 2-68

Drilled for State Hospital at Woodward, Iowa
 Between # 7 & # 8 test holes
 Well is located miles N-E-S-W and miles N-E-S-W from
 in the 1/4 Section 1/4 Township 4-24 Range 19-62
 Drilling started 4-24 1962 Completed 4-25 1962
 Well No. 1 Kind of Well Gravel Pack Depth 104 Size hole started 30" in.
 Finish 19" C. P. M. 450 Static Head 28' Pumping level from surface 46
 Water was first encountered at in Approx. Amt. 54° Temp. 54°
 Remarks _____

(GIVE DETAILS OF PERFORATED PIPE AND SEALS)

RECORD OF PERMANENT PIPE					TEMPORARY PIPE	
SIZE PIPE	AMOUNT OF PIPE	DEPTH TO BOTTOM OF PIPE	DEPTH TO TOP OF PIPE	MAKE OF PIPE	SIZE PIPE	AMOUNT
10"	91'	89'	2'	steel casing		
1 1/2"	105'	103'	2'			
12"	15'	104'	89'	Expand Screen		

Driller Guy Lemar From Surface to _____ feet
 Driller Elvin Greene From _____ feet to _____ feet
 Driller _____ From _____ feet to _____ feet

AMOUNT IN FEET	KIND OF SOIL OR FORMATION (BE SPECIFIC)	TOTAL DEPTH FEET
3	Top soil	3
6	Sandy yellow clay & gravel	9
76	Gray clay	85
19	Med. fine to coarse sand & gravel & boulders	104