

DE? IL OF WELL CON TRUCTION

WELL NO.5
CORALVILLE, IOWA

W-45527

LAYNE-WESTERN COMPANY, INC. - AMES, IOWA

JULY 1972

STATIC LEVEL: 44 FT.

CAPACITY: 170 G.P.M.

DRAWDOWN: 12 FT.

PUMPING LEVEL: 56 FT.

GEOLOGICAL LOG

CONSTRUCTION DETAIL

