

yellow copy - County Health Officer

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

Page (1)

WELL TEST DATA REPORT

Customer City Water Works City Oakville, Iowa
Location Park Street Well No. 2
Size Casing 8" Total Depth 158 Construction Steel
Make Pump Grundfos Model No. SP-45/20hp No. of Stages 6
Diameter 6" Total Setting 126' Air Line Length 126'
Meter Used 4" Static Level 11'

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
5-24-07	6:00am	340	12	1	340	60	Dirty 58°
	6:01	340	15	4	85	60	Dirty
	6:02	340	18	7	48.5	60	Dirty
	6:03	340	19	8	30	60	Dirty
	6:04	300	21	10	30	60	Dirty
	6:05	300	21	10	30	65	Cloudy
	6:06	300	20	9	33.3	67	Cloudy
	6:07	200	19	9	22.2	72	Cloudy
	6:08	200	19	8	25	75	Cloudy
	6:09	200	18	7	28.5	75	Clearing
	6:10	180	16	5	36	80	Clearing
	6:11	180	16	5	36	80	Clearing
	6:12	180	16	5	36	80	Clearing
	6:13	180	16	5	36	80	Clearing
	6:14	180	16	5	36	80	Clearing
	6:15	180	16	5	36	80	Clearing
	6:20	180	16	5	36	80	Clear
	6:25	180	16	5	36	80	Clear
	6:30	180	16	5	36	80	Clear
	6:35	180	16	5	36	80	Clear
	6:40	180	16	5	36	80	Clear
	6:45	180	16	5	36	80	Sand Content None
	6:55	180	16	5	36	80	Clear
	7:05	180	16	5	36	80	Clear
	7:15	180	16	5	36	80	Clear
	7:25	180	16	5	36	80	Clear
	7:35	180	16	5	36	80	Sand Content None

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

Page (2)

WELL TEST DATA REPORT

Customer	City Water Works		City	Oakville, Iowa	
Location	Park Street		Well No.	2	
Size Casing	8"	Total Depth	158	Construction	Steel
Make Pump	Grundfos	Model No.	SP-45/20hp	No. of Stages	6
Diameter	6"	Total Setting	126'	Air Line Length	126'
Meter Used	4"	Static Level	11'		

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
5-24-07	7:45am	180	16	5	36	80	Clear
	7:55	180	16	5	36	80	Clear
	8:05	180	16	5	36	80	Clear
	8:15	180	16	5	36	80	Clear
	8:25	180	16	5	36	80	Clear
	8:35	180	16	5	36	80	Clear
	8:45	180	16	5	36	80	Clear
	9:45	180	16	5	36	80	Clear
	10:45	180	16	5	36	80	Clear
	11:45	180	16	5	36	80	Sand Content None
	12:45pm	180	16	5	36	80	Clear
	1:45	180	16	5	36	80	Clear
	2:45	180	16	5	36	80	Clear
	3:45	180	16	5	36	80	Clear
	4:45	180	16	5	36	80	Clear
	5:45	180	16	5	36	80	Clear
	6:45	180	16	5	36	80	Clear
	7:45	180	16	5	36	80	Clear
	8:45	180	16	5	36	80	Sand Content None
	9:45	180	16	5	36	80	Clear
	10:45	180	16	5	36	80	Clear
	11:45	180	16	5	36	80	Clear
5-25-07	12:45am	180	16	5	36	80	Clear
	1:45	180	16	5	36	80	Clear
	2:45	180	16	5	36	80	Clear
	3:45	180	16	5	36	80	Clear
	4:45	180	16	5	36	80	Clear

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

Page (3)

WELL TEST DATA REPORT

Customer	City Water Works		City	Oakville, Iowa	
Location	Park Street		Well No.	2	
Size Casing	8"	Total Depth	158	Construction	Steel
Make Pump	Grundfos	Model No.	SP-45/20hp	No. of Stages	6
Diameter	6"	Total Setting	126'	Air Line Length	126'
Meter Used	4"	Static Level	11'		

[illegible]