
Sargent Drilling

INDUSTRIAL ENGINEERING COMPLETE MUNICIPAL AND INDUSTRIAL WELL AND PUMP SERVICE

PO Box 367 846 South 13th St. Geneva, NE 68361-0367 Phone: (402) 759-3902 Toll Free: (888) 496-3902 Fax: (402) 759-4960


Driller's Log

Customer:	Cherokee RWD, IA			Legal:		
Date Construction Started:		10/14/2003		GPS Reading:		
Well Depth: 251	•			Bore Hole	e:	24"
Type of Plain Casing:		.375" wall Steel		Casing Dia.:		12"
From: 0'		To 176'				
Type of Perf. Casing:		Stainless Stell V-Wire		Casing Dia.:		12"
Slot size: .030)"	From:	176'	To	251'	
Sump From:				Type of E	Bottom:	Stainless steel
Gravel From:				Grade Size:		#0
Yards of Gravel:	12			Bags of (Chunks:	3 Super Sacks
Bags of Powder:	24	}		Yards of	Concrete:	3
Stabilizers:	5			Well Development Time:):
Test Pump Results:				SWL:		
GPM from						
GPM from						
GPM from						
GPM from						



Cherokee Rural Water

1593 580th St. P.O. Box 1022 Cherokee, IA 51012 Ph. 712-225-6193 Fax 712-225-6195 Toll Free 1-877-470-6193 crwstan@ilechsi.com



Iowa Geo & Water Survey Attn: Paul Van Dorpe 109 Crow Bridge Hall Iowa City, IA 52242-1319

Date: August 17, 2009

Paul,

Enclose is the driller info you requested for our C-3 well. I see the driller called it Well # 7 by mistake. Let me know if any questions.

After reviewing the modeling info on the Dakota Sandstone, wondering what aquifer is next on your study list, and after doing more modiling, will you revise the Dakota study? Please let me know. Thanks.

Thanks..... Stan

Sargent Drilling

INDUSTRIAL ENGINEERING

COMPLETE MUNICIPAL AND INDUSTRIAL WELL AND PUMP SERVICE

PO Box 367 Geneva, NE 68361 846 S 13th St.

Phone: (402) 759-3902

1-888-496-3902

PUMP AND WELL INSTALLATION

Customer:

Cherokee RWD, IA

Date:

12/03/03

Address:

WELL:

Dia.:

#7

Location:

12"

Steel

Depth:

251'

GPS Reading:

Static Level: 17'

Casing Material:

MOTOR OR GEAR

DRIVE:

Mfg.: Serial No.: US

HP:

40

324TPM

Volts:

Phase:

Frame:

RPM:

1780

Clutch Bore:

1 1/2"

NRR:

Yes

Lower:

Bearings #'s:

Upper: N/A

7220-BEP

Length: N/A 6211-J Wire Size:

N/A

Sub. Dia.

Discharge

PUMP:

Mfg.:

Crown Column Dia.:

6"

Depth of Setting:

120'

Dia.:

6"

Shaft:

1 1/2"

Stainlees

Bowl Serial

No.:

MA50386-02

Dia.:

8"

Shaft material:

Steel

No. of

Length:

6"

7'

Type:

8H-500

Stages:

8 Suction

8"

Impeller: Strainer

Basket

Lubrication: Water

Airline Length

Water

7 @ Full & AC 1- B Trim Dia.:

120'

Material:

Mfg.:

Plastic

Length:

MISCELLANEOUS:

Does it work:

Yes

meter size: 6"

Does it

Sensus

Material:

Fainged/tube

work:

Yes

Blow off Dia.:

Dresser Sleeve Dia.:

None