

Page 1 of 2



AMES, IOWA 50010

Phone 515 232-3563

Job.....	City of Swea City.....	Well no.	3.....	Date Tested.....	12-11-84.....
Location.....	Water tower.....			Tested By.....	Heldt & Stockton.....
Dia. of Well.....	10".....			Driver.....	6-71 Detroit.....
Depth of Well.....	285'.....	Pump Used:		Column and Shaft.....	6 x 1 1/2.....
Length of Airline.....	125'.....			Bowls.....	10-stage 8" THC.....
Non-Pumping Level.....	27'.....			Manufacturer.....	Layne & Bowler.....
Orifice Size.....	6 x 3.....			Serial No.....	



Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

Job.....	Swea City	Well no.....	3	Date Tested	12-11-84
Location	Water tower			Tested By	Heldt & Stockton
Dia. of Well	10"			Driver	6-71 Detroit
Depth of Well	285'	Pump Used:		Column and Shaft	6 x 1 1/2
Length of Airline	125'			Bowls	10-stage 8" THC
Non-Pumping Level	27'			Manufacturer	Layne & Bowler
Orifice Size	6 x 3			Serial No.	

[illegible]