

WELL DRAWDOWN TEST

PUMP - DRAWDOWN TEST

[illegible]

Owner DAYBREAK - TRUCK WASH

Date 5/4/16 & 5/5/16

Address: 3170 BUCHANAN AVE
EAGLE GROVE, IA 50533

Well Size 8"

Well Depth 480 FT

Static Level 66 FT

Pump Water Level 113 FT

at GPM 85 FT

Casing Type STEEL

Other East well

Notes: FAST DRAWDOWN TO 110 FT
& FAST RECOVERY TO 66 FT

Certified Pump Tech LAYTON JUNKER CERTIFIED # 7114



1410 Gull Ave, P.O. Box 579
Latimer, IA 50452
641-579-6500

RECOVERY - RECHARGE TEST

[illegible]