

**Lewis & Clark Well Drawdown Log**

Test Performed 10/6/17

Initial Well Reading - Between 53 and 53.5

Pumping rate = 60 GPM

| <b>30 seconds first 5 minutes</b>       | <b>Drawdown</b> | <b>Time</b> |
|-----------------------------------------|-----------------|-------------|
| 30 seconds                              | 53              | 5:30:00 AM  |
| 30 seconds                              | 52              | 5:30:30 AM  |
| 30 seconds                              | 52              | 5:31:00 AM  |
| 30 seconds                              | 52              | 5:31:30 AM  |
| 30 seconds                              | 52              | 5:32:00 AM  |
| 30 seconds                              | 52              | 5:32:30 AM  |
| 30 seconds                              | 52              | 5:33:00 AM  |
| 30 seconds                              | 52              | 5:33:30 AM  |
| 30 seconds                              | 52              | 5:34:00 AM  |
| 30 seconds                              | 52              | 5:34:30 AM  |
| 30 seconds                              | 52              | 5:35:00 AM  |
| <b>5 minutes for next 55 minutes</b>    |                 |             |
| 5 minutes                               | 52              | 5:40 AM     |
| 5 minutes                               | 52              | 5:45 AM     |
| 5 minutes                               | 52              | 5:50 AM     |
| 5 minutes                               | 52              | 5:55 AM     |
| 5 minutes                               | 52              | 6:00 AM     |
| 5 minutes                               | 52              | 6:05 AM     |
| 5 minutes                               | 52              | 6:10 AM     |
| 5 minutes                               | 52              | 6:15 AM     |
| 5 minutes                               | 52              | 6:20 AM     |
| 5 minutes                               | 52              | 6:25 AM     |
| 5 minutes                               | 52              | 6:30 AM     |
| <b>15 minutes next 60 minutes</b>       |                 |             |
| 15 minutes                              | 52              | 6:45 AM     |
| 15 minutes                              | 52              | 7:00 AM     |
| 15 minutes                              | 52              | 7:15 AM     |
| 15 minutes                              | 52              | 7:30 AM     |
| <b>30 minutes 2 hours</b>               |                 |             |
| 30 minutes                              | 52              | 8:00 AM     |
| 30 minutes                              | 52              | 8:30 AM     |
| 30 minutes                              | 52              | 9:00 AM     |
| 30 minutes                              | 52              | 9:30 AM     |
| <b>60 minutes for remainder of test</b> |                 |             |
| 60 minutes                              | 52              | 10:30 AM    |
| 60 minutes                              | 52              | 11:30 AM    |
| 60 minutes                              | 52              | 12:30 PM    |
| 60 minutes                              | 52              | 1:30 PM     |
| 60 minutes                              | 52              | 2:30 PM     |
| 60 minutes                              | 52              | 3:30 PM     |
| 60 minutes                              | 52              | 4:30 PM     |
| 60 minutes                              | 52              | 5:30 PM     |

|            |    |          |
|------------|----|----------|
| 60 minutes | 52 | 6:30 PM  |
| 60 minutes | 52 | 7:30 PM  |
| 60 minutes | 52 | 8:30 PM  |
| 60 minutes | 52 | 9:30 PM  |
| 60 minutes | 52 | 10:30 PM |
| 60 minutes | 52 | 11:30 PM |
| 60 minutes | 52 | 12:30 AM |
| 60 minutes | 52 | 1:30 AM  |
| 60 minutes | 52 | 2:30 AM  |
| 60 minutes | 52 | 3:30 AM  |
| 60 minutes | 52 | 4:30 AM  |
| 60 minutes | 52 | 5:30 AM  |

Pump was stopped at 5:30 AM and the Well Recovered to the pretest reading within 60 seconds