

# Northway Well and Pump Co.

4895 8th Avenue  
Marion, Iowa 52302  
319-377-6339  
1-800-747-6339

100 North 6th Street  
Waukee, Iowa 50263  
515-987-4575  
1-800-747-4575

## WELL TEST DATA REPORT

Customer Jacobs Landing/ Freese Well City Shueyville, IA  
 Location Subdivision Well No. 2  
 Size Casing 8" Total Depth 530 Construction Steel/435 Feet  
 Make Pump Grundfos Model No. 150S200 No. of Stages 10  
 Diameter 6" Total Setting 430 Air Line Length 430  
 Meter Used 3" Meter Static Level 260

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
3-23-2018	10:30	85	280	20	4.25	75	Clear TDS 920
	10:40	85	290	30	2.73	75	TDS 870
	10:45	52	354	94	0.55	60	TDS 1040
	11:00	52	375	115	0.45	60	TDS 1220
	11:15	52	392	132	0.34	60	TDS 1200
	11:30	52	409	149	0.34	60	TDS 1160
	11:45	52	409	149	0.34	60	TDS 1150
	12:00	52	409	149	0.34	60	TDS 1130
	12:15	52	409	149	0.34	60	TDS 1120
	12:30	52	409	149	0.34	60	TDS 1100
	1:00	52	409	149	0.34	60	TDS 1090
	1:15	52	410	150	0.34	60	TDS 1070
	1:30	52	410	150	0.34	60	TDS 990
	2:00	52	410	150	0.34	60	TDS 940
	Pump OFF						
Recovery	2:01		373				
	2:02		362				
	2:03		349				
	2:04		331				
	2:05		326				
	2:06		315				
	2:07		317				
	2:08		306				
	2:09		295				
	2:10		286				

Note: TDS indicates some turbidity in the well from the air shock and acid treatment.

100 North 6th Street  
Waukee, Iowa 50263  
515-987-4575  
1-800-747-4575

**PAGE -2-**

Customer \_\_\_\_\_ City \_\_\_\_\_  
Location \_\_\_\_\_ Well No. \_\_\_\_\_

[illegible]